

Final

2011 Annual Monitoring Report

Northern Cities Management Area

Submitted to: The Northern Cities
Management Area Technical Group

City of Arroyo Grande, City of Grover Beach, City of
Pismo Beach, and the Oceano Community Services
District, San Luis Obispo County, California


Date: May 4, 2012
Project No: 116660

Robert Almy, PG
Project Director

2011 Annual Monitoring Report

for the
Northern Cities Management Area
May 2012

This report was prepared by the staff of GEI Consultants, Inc. under the supervision of professionals whose signatures appear hereon. The findings or professional opinions were prepared in accordance with generally accepted professional engineering and geologic practice.



A handwritten signature of Robert Almy in cursive script, positioned above a horizontal line.

Robert Almy, PG
Project Director



A handwritten signature of Samuel W. Schaefer in cursive script, positioned above a horizontal line.

Samuel W. Schaefer, PE
Senior Engineer

Table of Contents

1	Introduction	1
2	Climate Conditions	3
2.1	Precipitation	3
2.2	Evapotranspiration	4
3	Water Demand	5
3.1	Urban Demand	5
3.2	Applied Irrigation Demand	6
3.3	Rural Demand	8
3.4	Changes in Water Demand	8
4	Water Supply Sources	9
4.1	Sources of Supply	9
4.1.1	Lopez Lake Supply	9
4.1.2	State Water Project	10
4.1.3	Groundwater	10
4.1.4	Developed Water	11
4.1.5	Water Use by Supply Source	12
4.2	Groundwater Conditions	13
4.2.1	Groundwater Monitoring Network	13
4.2.2	Groundwater Levels	14
4.2.3	Water Quality	16
4.3	Threats to Water Supply	30
4.3.1	Threats to State Water Project Supply	30
4.3.2	Seawater Intrusion	31
4.3.3	Measures to Avoid Seawater Intrusion	32
4.3.4	Change in Groundwater Recharge	32
5	Supply/Demand Comparison	34
6	Management Activities	36
6.1	Management Objectives	36
6.1.1	Share Groundwater Resources and Manage Pumping.	38
6.1.2	Monitor Supply and Demand and Share Information	39
6.1.3	Manage Groundwater Levels and Prevent Seawater Intrusion	39
6.1.4	Protect Groundwater Quality	40
6.1.5	Encourage Water Conservation	41
6.1.6	Manage Cooperatively	41
6.1.7	Other Potential Management Objectives	41
6.2	Update on Management Activities	42

6.2.1	Expansion of Groundwater Monitoring	42
6.2.2	Control of Groundwater Levels and Seawater Intrusion	42
6.2.3	Cooperative Water Supply Planning and Management	42
6.2.4	Water Conservation	43
6.2.5	Alternative Water Supply Studies	46

7 References Cited **48**

Tables

Table 1	Total Demand for Groundwater and Surface Water, AFY	5
Table 2	Gross Irrigation Requirement for WPA 5 by Crop Group	7
Table 3	Estimated Rural Water Demand	8
Table 4	Zone 3 Contractor Water Entitlement (AFY)	9
Table 5	Available Urban Water Supplies, AFY	12
Table 6a	Northern Cities Sentry Well Water Quality Data Summary	18
Table 6b	Northern Cities Sentry Well Water Quality Data Summary	23
Table 7	2011 Water Demand by Source (AF)	34

Figures

Figure 1	Santa Maria River Valley Groundwater Basin
Figure 2	Northern Cities Management Area
Figure 3	Annual Precipitation 1950 to 2011
Figure 4	Monthly 2011 and Average Precipitation and Evapotranspiration
Figure 5	Municipal Water Use by Source
Figure 6	Total Water Use by Source
Figure 7	Location of Sentry Wells
Figure 8	Depths of Sentry Wells
Figure 9A	Groundwater Elevation Contours Spring 2011
Figure 9B	Groundwater Elevation Contours Fall 2011
Figure 10	Selected Well Hydrographs
Figure 11	Sentry Well Hydrographs
Figure 12A	Hydrograph of Average Deep Sentry Well Elevations
Figure 12B	Water Elevation, Conductivity, and Temperature, Well 24B01
Figure 12C	Water Elevation, Conductivity, and Temperature, Well 24B03
Figure 12D	Water Elevation, Conductivity, and Temperature, Well 30F03
Figure 12E	Water Elevation, Conductivity, and Temperature, Well 30N02
Figure 13	Chloride Concentrations over Time in Sentry Wells
Figure 14	Total Dissolved Solids Concentrations over Time in Sentry Wells
Figure 15	Schoeller Diagram for Sentry Well 30N02, 2010-2012

1 Introduction

This report summarizes hydrologic conditions in the Northern Cities Management Area (NCMA) of the Santa Maria Groundwater Basin in San Luis Obispo County (County), California on behalf of four public agencies, specifically the City of Arroyo Grande (Arroyo Grande), City of Grover Beach (Grover Beach), City of Pismo Beach (Pismo Beach) and the Oceano Community Services District (Oceano CSD), (Northern Cities). These agencies, along with local land owners, the County of San Luis Obispo (County), and the San Luis Obispo County Flood Control & Water Conservation District (FC&WCD) have managed local surface water and groundwater resources since the late 1970s to preserve the long-term integrity of water supplies.

This longstanding approach was formalized in the 2002 Settlement Agreement among the Northern Cities, Northern Landowners, and Other Parties, and incorporated in the 2005 Settlement Stipulation for the Santa Maria Groundwater Basin Adjudication (Stipulation). The June 30, 2005 Stipulation was agreed upon by numerous parties, including the Northern Cities. The approach was then adopted by the Superior Court of California, County of Santa Clara, in its *Judgment After Trial*, entered January 25, 2008 (Judgment). Figure 1 shows the four Northern Cities relative to the Santa Maria Valley groundwater basin, as defined in the adjudication and the Santa Maria River Valley groundwater basin (Basin 3-12) as defined by the Department of Water Resources (DWR).

The Judgment orders the stipulating parties to comply with all terms of the Stipulation. The 2002 Settlement Agreement is generally affirmed as part of the Judgment and its terms incorporated into the Stipulation. However provisions of the Stipulation supersede the 2002 settlement agreement in the areas of continuing jurisdiction and groundwater monitoring, reporting.

As specified in the Judgment, the Northern Cities agencies conduct groundwater monitoring in the Northern Cities Management Area. As shown in Figure 2, the Northern Cities Management Area (NCMA) represents the northernmost portion of the Santa Maria Groundwater Basin. Adjoining the NCMA to the southeast is the Nipomo Mesa Management Area (NMMA), while the Santa Maria Valley Management Area encompasses the remainder of the groundwater basin.

In accordance with requirements of the Judgment, the agencies comprising the NCMA group collect and analyze data pertinent to water supply and demand, including:

- Land and water uses in the basin
- Sources of supply to meet those uses
- Groundwater conditions (including water levels and water quality)

The Monitoring Program gathers and compiles pertinent information on a calendar year basis through requests to public agencies, necessary field work, and from online sources. Periodic reports such as Urban Water Management Plans (UWMP) prepared by the Cities of Arroyo Grande, Grover Beach and Pismo Beach provide information on planning to meet future demand. Annual data are added to the comprehensive Northern Cities Management Area Database (NCMA DB) and analyzed. Results of the data compilation and analysis for calendar year 2011 are documented and discussed in this Annual Report.

2 Climate Conditions

Figure 4 shows monthly rainfall and evapotranspiration for 2011, and for comparison, average monthly historical rainfall and evapotranspiration. Each year climatalogic (weather) and hydrologic (stream flow) data for the NCMA are added to the NCMA DB. These data are discussed below.

2.1 Precipitation

Historical rainfall data have been compiled on a monthly basis for the National Oceanic and Atmospheric Administration (NOAA) Pismo Beach station for 1949 to 2005, while precipitation data from 2005 to present are available from a County-operated rain gage in Oceano. Figure 3 is a composite graph combining data from the two stations and illustrating annual rainfall totals from 1950 through 2011 (on a calendar year basis). Annual average rainfall for the NCMA is approximately 16 inches.

Above average rainfall occurred during the months of March, May, and June of 2011, however the total rainfall for 2011 was only 78.8 percent of the average annual rainfall. This follows the period from 2007 through 2009, during which the precipitation conditions within the NCMA were the second driest on record, and 2010, during which the precipitation totals within NCMA were the seventh highest on record, going back to 1950. The average three year precipitation for the period from 2007 through 2009 was only slightly higher than the average precipitation for the driest three year period on record, which ended in 1990. In 2010, the total precipitation was 163 percent of the average annual rainfall. Inspection of Figure 3 plots annual rainfall and shows several multi-year drought cycles followed by cycles of above average rainfall (such as occurred from March 1991 to March 1998).

Figure 4 shows monthly rainfall and evapotranspiration data on a calendar year basis for 2011 and, for comparison, the average monthly rainfall. Most rainfall typically occurs from November through April. The year 2011 was marked by substantially lower than average rainfall in January, February, April, and December, while rainfall in the months of March, May and June were above average. The remaining months, most of which were in the dry season, experienced slightly below average rainfall. Rainfall only exceeded evapotranspiration in March, 2011. Deep percolation, thus groundwater recharge, would have occurred during March, given that rainfall penetrated below the vegetation's root zone.

2.2 Evapotranspiration

The California Irrigation Management Information System (CIMIS) maintains weather stations in locations throughout the state in order to provide real time wind speed, humidity and evapotranspiration data. Nipomo and San Luis Obispo stations have gathered data since 2006 and 1986, respectively. Monthly ET data from the two stations is shown in Figure 4 for 2011 and average conditions. Evapotranspiration rate affects recharge potential of rainfall and the amount of outdoor water use (irrigation).

3 Water Demand

Water demand refers to the total amount of water used to satisfy various needs. In the NCMA, water is primarily used to satisfy urban demand and applied irrigation demand. The third category, rural demand includes small community water systems, domestic, recreational and agriculture-related businesses and is relatively minor. Table 1 presents water demands for urban uses, applied irrigation, and rural uses. The values shown in Table 1 represent water demand in acre-feet per year (AFY). Comparing demand to available supply (Section 4) allows development and comparison of water source options under a given set of conditions.

Table 1 Total Demand for Groundwater and Surface Water, AFY

Year	Arroyo Grande	Grover Beach	Pismo Beach	Oceano CSD	Total Urban	Applied Irrigation	Rural Water	Total Demand
2005	3,460	2,082	2,142	931	8,615	2,056	36	10,707
2006	3,425	2,025	2,121	882	8,453	2,056	36	10,545
2007	3,690	2,087	2,261	944	8,982	2,742	36	11,760
2008	3,579	2,051	2,208	933	8,771	2,742	36	11,549
2009	3,315	1,941	2,039	885	8,180	2,742	36	10,958
2010	2,956	1,787	1,944	855	7,542	2,056	38	9,636
2011	2,922	1,787	1,912	852	7,473	2,742	38	10,253

3.1 Urban Demand

Actual urban water demands are presented in Table 1 for each of the Northern Cities from 2005 through 2011. These demand values reflect reported Lopez Lake and State Water Project (SWP) purchases and groundwater production data, which are incorporated in the NCMA database. These water demand values represent all water used within the entire service areas of the four agencies comprising Northern Cities, including the portions of Arroyo Grande and Pismo Beach that extend outside the NCMA (Figure 2). Urban demand amounts reported include water delivered to municipal customers and all other water used by the respective municipal agency as well as system losses.

3.2 Applied Irrigation Demand

Applied Irrigation Demand is an in-direct measurement that requires a method for estimating Annual Gross Irrigation Water Requirement (AGIR). The San Luis Obispo County Water Master Plan uses a crop-specific method for calculating AGIR in acre-feet per year per acre (AFY/acre), based on crop evapotranspiration, effective rainfall, leaching requirements, irrigation efficiency, and frost protection. Calculation of the AGIR, which is then used to estimate the applied water for irrigation for an aggregated area, is described in the following equation:

$$\text{AGIR (Ft)} = [(\text{Crop ET} - \text{Effective Rainfall}) / ((1 - \text{Leaching Requirement}) \times \text{Irrigation Efficiency})] + \text{Frost Protection Water}$$

The calculated crop-specific applied water is multiplied by specific crop acres to obtain the irrigation demand for a given crop type. The individual crop demands are then summed for the agricultural area of interest. The San Luis Obispo County Water Master Plan is currently being completed and will contain a determination of irrigated acres by a GIS method for areas in the county, with the exception of the NCMA, NMMA, and the SMVMA areas, since these areas had completed their own land use determinations.

In the NCMA, annual crop statistics are aggregated into crop categories and the specific farm field location is not published or readily available; thus, the necessary land use data with crop-specific surveys are not available at this time to be used to calculate the annual irrigation demand based on the crop survey information. The representative land use survey information provides an estimate of crop-specific acres that are aggregated into larger categories, such as, truck crops. In order to estimate the annual irrigation demand for the NCMA, the crop acres represented by an aggregated category are multiplied by the estimated gross irrigation requirements per acre from the San Luis Obispo County Water Master Plan.

The 2011 annual report estimates the applied irrigation demand based on the method established in the previous annual reports completed by Todd Engineers. The estimate of gross irrigation requirements is based on the San Luis Obispo County Water Master Plan Update which includes low, average, and high estimates of irrigation demand by crop type for each of the Water Planning Areas (WPAs) in the County. The range in estimated irrigation demands is based upon climactic conditions and average irrigation efficiency, and includes double cropping for the category truck crops. Since the Water Master Plan Update does not include gross irrigation requirements for turf grass, the values for pasture grass were applied to turf grass areas in the NCMA to estimate their applied irrigation demand, recognizing that pasture grass is the most similar to turf grass. The representative gross irrigation requirements for crop groups are presented in Table 2.

As stated in the previous Annual Report, the areal extent of cultivated agricultural areas in the NCMA has been quantified using a past land use survey by the San Luis Obispo County Agricultural Commission. Communication with the San Luis Obispo Agricultural

Commission Office conferred the observation that agriculture land use in the NCMA for 2011 has remained consistent for the past several years. Given this observation, the estimated agriculture acreage remained based on agriculture land use survey data and the methods used by Todd Engineers. The San Luis Obispo Agriculture Office indicated agriculture land use data, updated by their GIS staff, may become available in future years. For the 2011 estimate, the same land use acres were used to calculate the applied irrigation demand as identified in the previous annual report. The areas with irrigated turf grass have been previously identified by public works personnel within the Northern Cities. The acreages of these areas have been measured from publically available aerial photographs using GIS software tools.

Table 2 Gross Irrigation Requirement for WPA 5 by Crop Group

Crop Type	Low Annual Demand (AFY/acre)	Average Annual Demand (AFY/acre)	High Annual Demand (AFY/acre)
Alfalfa	2.5	2.9	3.3
Nursery	1.4	1.7	2.1
Pasture	2.6	3.0	3.5
Turf Grass	2.6	3.0	3.5
Citrus	1.3	1.6	1.9
Deciduous	2.6	2.9	3.2
Truck (vegetable)	1.2	1.4	1.6
Vineyard	0.9	1.1	1.4

The 2011 agricultural water demand in NCMA is based on previous year estimates for land use and since the acres of land use have no indication they have changed. There are about 1,600 acres of irrigated agriculture within the NCMA of which approximately four acres are in nursery crops, and the remainder is truck crops such as broccoli, onions, and strawberries, the total acres for irrigated crops in the NCMA. There is a combined total of 44 acres of irrigated turf grass at the Oceano Elementary School, Arroyo Grande High School, Harloe Elementary School, and the Le Sage Riviera Golf Course. For 2011, the annual precipitation and evapotranspiration have been compared to average conditions to determine if the year in question had a low, average, or high irrigation water demand.

For this evaluation, average irrigation efficiencies are assumed for the NCMA. Therefore, the annual irrigation demand for each crop type is assumed to be dependant only on that year's precipitation and evapotranspiration. The range of demand estimates for all applied irrigation uses are as follows:

- Wet years: 2,056 AFY (2005, 2006, and 2010)
- Average years: 2,397 AFY (2004)
- Dry years: 2,742 AFY (2007, 2008, 2009, and 2011)

3.3 Rural Demand

In the NCMA rural water demand refers to uses not designated as urban demand or applied irrigation demand and includes small community water systems, individual domestic system, recreational uses and agriculture-related business systems. Small community water systems using groundwater in the NCMA were identified initially through review of a list of water purveyors compiled in the 2007 San Luis Obispo County Integrated Regional Water Management Plan. These include the Halcyon Water System, Ken Mar Gardens, and Pacific Dunes RV Resort. The Halcyon Water System serves 35 homes in the community of Halcyon, while Ken Mar Gardens provides water supply to 48 mobile homes on South Halcyon Road. The Pacific Dunes RV Resort, with 215 RV sites, provides water supply to a largely transitory population and nearby riding stable. In addition, about 25 homes and businesses have been identified through inspection of aerial photographs of rural areas within NCMA. Irrigation of schools and parks from privately operated wells is included in the applied irrigation demand section. Two mobile home communities, Grande Mobile and Halcyon Estates, are served by Oceano CSD through the distribution system of Arroyo Grande. The demand summary of Oceano CSD includes these two communities. Based on prior reports, it is assumed that the number of private wells is negligible within the service areas of the four Northern Cities. The estimated rural water demand is shown in Table 3.

Table 3 Estimated Rural Water Demand

Groundwater User	No. of Units	Estimated Water Demand, AFY per Unit	Estimated Water Demand, AFY	Notes
Halcyon Water System	35	0.40	14	1
Ken Mar Gardens	48	0.18	8.7	2
Pacific Dunes RV Resort	215	0.03	6	3
Rural Users	25	0.40	10	1
Current Estimated Rural Use			38	

1 - Water demand/unit based on 2000 and 2005 Grover Beach water use per connection, 2005 UWMP.

2 - Demand based on metered water usage.

3 - Water demand/unit assumes 50 percent annual occupancy and 0.06 AFY per occupied site.

3.4 Changes in Water Demand

In general, urban water demand has varied, with a slight decrease during the past couple years (Table 1). This change is attributed primarily to the relatively slower economy and the conservation activities implemented by the Northern Cities in response to the prolonged drought and potential threat of seawater intrusion. In the applied irrigation category, agricultural acreage has remained fairly constant. Thus annual water demand for applied irrigation varies mostly with weather conditions. Acknowledging the variability due to weather conditions (see Table 1), applied irrigation water demand is not expected to change significantly, given the relative stability of applied irrigation acreage and cropping patterns in the NCMA south of Arroyo Grande Creek. Changes in rural demand have not been significant.

4 Water Supply Sources

Section 4 provides an overview of NCMA water supply sources, presents groundwater conditions that occurred in 2011, and discusses threats to water supply.

4.1 Sources of Supply

There are three major sources of water that supply the NCMA. These are the Lopez Lake, the State Water Project Coastal Branch, and groundwater pumping. Each source of supply has a defined delivery volume which varies from year to year based on a number of factors. Both supply and demand are discussed below; demand is discussed in further detail in Section 5.

4.1.1 Lopez Lake Supply

Lopez Lake and Water Treatment Plant is operated by FC&WCD Zone 3 and serves water to all four agencies in the NCMA as well as making releases for habitat conservation and agricultural purposes. The safe yield of Lopez Lake is 8,730 AFY, which reflects the amount of sustainable water supply during a drought of defined severity. Of this yield, 4,530 AFY have been apportioned by agreements to contractors, including each of the Northern Cities plus County Service Area (CSA) 12 (in the Avila Beach area). Zone 3 entitlements are summarized in Table 4. Of the safe yield, 4,200 AFY is available for release downstream to maintain flows in Arroyo Grande Creek and provide groundwater recharge.

Table 4 Zone 3 Contractor Water Entitlement (AFY)

Contractor	Water Entitlement, (AFY)
City of Arroyo Grande	2,290
City of Grover Beach	800
City of Pismo Beach	896
Oceano CSD	303
CSA 12 (not in NCMA)	241
Total	4,530
<i>Downstream Releases</i>	<i>4,200</i>
<i>Safe Yield of Lopez Lake</i>	<i>8,730</i>

Source: SLO County FC&WCD, Zone 3 UWMP 2005 Update

During 2011 the total discharge from Lopez Lake was 7418.4 AF, of which 4,606.8 AF was delivered to contractors and 2,811.6 AF was released downstream to maintain flow in Arroyo Grande Creek (actual deliveries are shown in Table 7). In the past, when management of

releases resulted in a portion of the 4,200 AFY remaining in the reservoir, the water was offered to the contractors as surplus water. Surplus water was available in 2011; the NCMA agencies took 2,226.5 AF of delivery.

4.1.2 State Water Project

Pismo Beach and Oceano CSD have contracts with the FC&WCD to receive water from the SWP. The FC&WCD serves as the SWP contractor, providing the imported water to local retailers through the Coastal Branch pipeline. Pismo Beach has a contractual allocation of 1,240 AFY while Oceano CSD has a contractual allocation of 750 AFY. The FC&WCD holds SWP allocation in excess of the amount contracted for delivery to local agencies. This allocation (sometimes referred to as a “drought buffer”) is available to augment requests when the state wide SWP allocations are insufficient to meet local needs.

In response to drought in SWP source areas, the initial allocation to SWP contractors for 2011 was 25 percent of contractual allocation amounts, which was subsequently increased to 70 percent in March, and ultimately 80 percent in May due to above average precipitation in late 2010 and spring 2011. However, due to the nature of its contractual arrangements, FC&WCD needed to request only a fraction of its entire 25,000 AF allocation in 2011 to satisfy local contractors. The requested amount met all of the local purveyors’ requests. Unlike many water agencies in California that have experienced substantial restrictions in SWP deliveries, Pismo Beach and Oceano CSD (the only SWP participants in the NCMA) were both able to receive 100 percent of their requested 2011 SWP allocation. Pismo Beach actually took delivery of 809.4 AF, while Oceano CSD took delivery of 750.0 AF, for a total of 1,559.4 AF of SWP water (Shown in Table 7, rounded to the nearest AF).

4.1.3 Groundwater

Each of the NCMA agencies have established groundwater supplies using wells which draw from developed aquifers in the northern portion of the NCMA. Groundwater also supplies applied irrigation and rural uses in the NCMA. Groundwater use in the NCMA is governed by the Judgment and the 2002 Settlement Agreement which establishes that groundwater will continue to be allotted and independently managed by the “Northern Parties” (Northern Cities, NCMA overlying owners, and the FC&WCD). The Settlement Agreement initially allots 57 percent of groundwater safe yield to agriculture and 43 percent to the cities and stipulates that any increase or decrease in groundwater yield will be shared by the cities and landowners on a pro rata basis. However the Judgment after Trial, filed January 25, 2008 states:

4. (a) The Northern Cities have a prior and paramount right to produce 7,300 acre-feet of water per year from the Northern Cities Area of the Basin; and (b) the Non-Stipulating parties have no overlying, appropriative, or other right to produce any water supplies in the Northern Cities Area of the Basin.

A safe yield value of 9,500 AFY for the NCMA groundwater basin was cited in the 2002 Groundwater Management Agreement among the Northern Cities with allotments for applied irrigation (5,300 AFY), subsurface outflow to the ocean (200 AFY), and urban use (4,000 AFY). The Management Agreement's safe yield allotment for urban use was subdivided as follows:

- City of Arroyo Grande 1,202 AFY
- City of Grover Beach 1,198 AFY
- City of Pismo Beach 700 AFY
- Oceano Community Services District 900 AFY

According to the "Water Balance Report" prepared for NCMA in 2007 (Todd Engineers, 2007), the *Groundwater Management Agreement's* subdivision for applied irrigation is higher than the actual applied irrigation groundwater use and the amount designated for subsurface outflow is unreasonably low. Since the amount of agriculture expansion is not significant and the long term increased use is unlikely, the current balance of water use between agriculture and municipal uses has been sustainable for the last 40 years. Maintenance of subsurface outflow along the coast is essential to preventing seawater intrusion. While the minimum subsurface outflow needed to prevent seawater intrusion is unknown, a regional outflow on the order of 3,000 AFY has been estimated as a reasonable approximation (Todd Engineers, 2007).

The 2002 Settlement Agreement provides that the various urban parties' allotments can be increased when land within the corporate boundaries is converted from agricultural uses to urban uses, referred to as an agricultural conversion credit. Agricultural credits for the Cities of Arroyo Grande and Grover Beach changed slightly from 2010. The agricultural credit for 2011 for Arroyo Grande and Grover Beach and are 121 AFY and 209 AFY, respectively, for a total of 330 AFY.

4.1.4 Developed Water

As defined in the Stipulation, "developed water" is "Groundwater derived from human intervention" and includes "Lopez Lake Water, Return Flow, and recharge resulting from storm water percolation ponds." Return flows result from deep percolation of water used in irrigation that is in excess of plant needs. Return flows result from outdoor uses of Lopez Lake and SWP deliveries. These return flows have not been recently estimated, but would be considered part of the groundwater basin yield.

In 2008, the Cities of Arroyo Grande, Grover Beach, and Pismo Beach prepared storm water management plans; the cities currently are working with the Central Coast Regional Water Quality Control Board to address local storm water quality issues. In order to control storm water runoff, each City anticipates development of retention or detention ponds associated with new development that may provide groundwater recharge. No new ponds were installed

in the NCMA and no new data were available for 2011 so previous estimates of recharge were used in this report. Estimated recharge values should be updated and refined as new recharge facilities are installed and as additional information on flow rates, pond size, infiltration rates, and tributary watershed area becomes available.

Construction of recharge basins or other means to increase groundwater recharge could substantially augment the yield of the groundwater basin and thus warrant provision of recharge credits to one of more of the Northern Cities. Pursuant to the Settlement agreement, recharge credits would be based on a mutually-accepted methodology to evaluate the amount of recharge. This would involve quantification of such factors as Lopez Lake and State Water Recharge, storm water runoff amounts, determination of effective recharge under various conditions, and methods to document actual recharge to developed aquifers.

4.1.5 Water Use by Supply Source

Table 5 summarizes the water supplies currently available to the Northern Cities in terms of Lopez Lake entitlements, SWP allocations, groundwater allotments, and agricultural credits. In addition to directly available supplies, 2011 was the 3rd year of a 5 year agreement between Arroyo Grande and Oceano CSD for the temporary purchase of groundwater or Lopez Lake supplies. The category of “Other Supplies” includes groundwater pumped outside the NCMA boundaries.

Table 5 Available Urban Water Supplies, AFY

Urban Area	Lopez Lake Entitlement	SWP Allocation	Groundwater Allotment	Ag Credit	Temporarily Purchased	Other Supplies	Total
Arroyo Grande	2,290	0	1,202	121	100	160	3,873
Grover Beach	800	0	1,198	209	0	0	2,207
Pismo Beach	896	1,240	700	0	0	0	2,836
Oceano CSD	303	750	900	0	-100	0	1,853
Total	4,289	1,990	4,000	330	0	160	10,769

Figure 5 illustrates the water use by supply source for each NCMA city since 1999. The graphs reveal changes in water supply availability and use over time, including the increased use of SWP water (to a maximum in 2001) and reduced and less variable Lopez Lake water use due to the unavailability of Lopez Lake surplus flows from 2002 to 2008. No recycled water was available in 2011. Plans have been developed to provide recycled water facilities. See Section 6.2.5.

Figure 6 shows total NCMA water use for each supply source: Lopez Lake, SWP, and groundwater. As shown, the full amount of Lopez Lake supply (4,289 AFY) is currently used. In 2001 through 2003, SWP supplies (1,850 AFY) were used to the maximum extent. From 2004 to 2008, SWP use decreased to just over 1,100 AFY, mostly reflecting a partial

shift by Pismo Beach from SWP to groundwater supply. This changed in 2009 and 2010 when Pismo Beach increased SWP use and significantly decreased groundwater use to provide a more economical water supply and to ease the burden on the groundwater basin during the drought (see Figure 5). In 2011 Pismo Beach took delivery of 809.40 AF of SWP water and pumped 47.11 AF from the groundwater basin. In 2011 Oceano CSD took delivery of 750.00 AF of SWP water and pumped 44.28 AF from the groundwater basin.

Total NCMA groundwater use is shown in Figure 6. Estimated applied irrigation and rural uses are added to the urban uses detailed in Figure 5. From 1999 through 2011, total estimated groundwater use averaged approximately 5,165 AFY and exceeded 6,000 AFY in 2007 and 2008. With an estimated safe yield of 9,500 AFY, the remaining groundwater represents storage and outflow to the ocean, an unknown but major portion of which is needed to repel seawater intrusion. The overall groundwater use in 2009 was slightly above average, though in 2010 and 2011 overall groundwater use was significantly reduced and remained below average.

4.2 Groundwater Conditions

The NCMA groundwater monitoring program comprises: 1) compilation of groundwater elevation data from San Luis Obispo County, 2) water quality and groundwater elevation monitoring data from the network of sentry wells in the NCMA, 3) water quality data from the California Department of Public Health (DPH), and 4) groundwater elevation data from municipal pumping wells. Analysis of these data is summarized below in accordance with the July 2008 *Northern Cities Monitoring Program*.

4.2.1 Groundwater Monitoring Network

Approximately 145 wells within the NCMA were monitored by the County at some time during the past few decades. The County currently monitors 38 wells on a semi-annual basis (April and October), including five “sentry well” clusters (piezometers) located along the coast. The County monitors more than 70 additional wells in southern San Luis Obispo County. Following the findings of the 2008 Annual Report, the Northern Cities initiated a quarterly sentry well monitoring program to supplement the County’s semi-annual schedule.

To monitor overall changes in groundwater conditions, representative wells within the NCMA were selected for preparation of hydrographs and evaluation of water level changes. Wells were selected based on the following criteria:

- Part of the County’s current monitoring program
- Detailed location information available
- Geographically well distributed
- Long and relatively complete record

It should be noted that many of the wells that have been measured are production wells that were not designed for monitoring purposes and may be screened in various producing zones. Moreover, many of the wells are active production wells or located near active wells and thus are subject localized pumping effects that result in measurements that are lower than the “static” or more broadly representative water level. These effects are not always apparent at the time of measurement. As a result, the data cannot easily be identified as representing static groundwater levels in specific zones (e.g., unconfined or deep confined). Hence, the data should be considered as a whole in developing a general representation of groundwater conditions.

The “sentry wells”, shown on Figure 7, are a critical element of the groundwater monitoring network; they provide an early warning system to identify and quantify potential seawater intrusion episodes in the basin. Each sentry well comprises a cluster of multiple wells allowing for the measurement of groundwater elevation and quality from discrete depths. Also shown on Figure 7 is the Oceano CSD Observation well, a dedicated monitor well cluster located just seaward of Oceano CSD production wells 7 and 8. Figure 8 shows the depth and well names of the sentry well clusters and the Oceano CSD observation well cluster. The wells are divided into three basic depth categories: shallow, intermediate, and deep. Since the initiation of the sentry well monitoring program 12 quarterly events have been completed; with one each in May, August, and October 2009 and winter, spring, summer and fall 2010 and 2011 and one in January 2012. These monitoring events include collection of synoptic groundwater elevation data and water quality samples for laboratory analysis.

4.2.2 Groundwater Levels

Groundwater elevation data is gathered from the network of wells listed in Table 6a and 6b. Water level measurements in these wells were used to monitor effects of groundwater use, groundwater recharge, and as an indicator of risk of seawater intrusion. Analysis of these groundwater elevation data has included development of groundwater surface contour maps, hydrographs, and an index of key sentry well levels over time (Figures 9 through 12).

Contoured groundwater elevations for the April (Spring 2011) and November (Fall 2011) monitoring events, including data from the County of San Luis Obispo, are shown on Figures 9A and 9B. Figure 9A shows groundwater elevations for Spring 2011 highest in the eastern portion of the NCMA and approximately 10 feet above sea level along the shore line. No comparison with prior years is possible since this is the first year Spring contours were prepared.

Groundwater elevations in November 2011 (Figure 9B) were highest in the eastern portion of the NCMA near Arroyo Grande and Highway 101. Groundwater elevations were above mean sea level (msl) throughout the NCMA during the November monitoring event. Significantly, water level elevations were approximately 5 feet above sea level along the shoreline. This represents a significant recovery of groundwater elevations as compared to October 2008 and

above levels measured in October 2009. The water levels are similar to those measured in 2010. This recovery is important because in October 2008 water level elevations were as much as 10 feet below sea level in the north-central portion of the NCMA (Todd Engineers, 2009). Because the area below mean sea level appeared to extend to the coast there was potential for seawater intrusion (Todd Engineers, 2008). However, there remains an apparent depression in the water table in the so-called “pumping trough” which is located well south of the municipal well fields.

Figure 10 shows the locations of selected wells. Hydrographs shown on Figure 10 illustrate long-term changes in groundwater levels in the NCMA. To provide geographic context, hydrographs from wells located just east of the NCMA in the Nipomo Mesa Management Area as presented as well. Noting that these hydrographs represent localized conditions at each well, most of the hydrographs indicate that groundwater elevations have historically varied over a range of about 20 feet above mean sea level and in the case of two inland wells, 40 feet.

The upper left and middle left portions of Figure 10 shows paired hydrographs for four wells located near a persistent pumping trough. (It should be noted that these wells are near municipal well fields and, depending on duration of pumping, water levels may remain below levels in other areas of the basin for prolonged periods of time.) Although the data sets are incomplete, the hydrographs show that, throughout the record, groundwater elevations in these wells have generally been above mean sea level. However, an area of lower groundwater elevations (“trough”) beneath the active well field became more pronounced during the period of reduced rainfall in 2007 and 2008. These wells remained above sea level in 2011.

Most of the hydrographs in Figure 10 show that groundwater elevations have recovered and remained at levels similar to 2006 (a wet year); this cycle shows the result of drought and increased pumping followed by recovery caused by increased rainfall and decreased pumping (see Figure 6). Although somewhat above sea level, a depression in groundwater levels persists in the area of the trough suggesting that the recharge and withdrawals are near balance in the area. Changes in groundwater elevations within the NCMA that occurred from October 2008 to October 2011 have been evaluated in the preparation of this report. Overall, water elevations within the NCMA remained constant during water year 2011 compared to similar periods in 2010 with relatively insignificant increases or decreases in elevation in some areas.

The sentry well clusters are the essential tool for tracking critical groundwater elevation changes at the coast. As shown by the hydrographs for the five sentry well clusters in Figure 11, the sentry wells provide a long history of groundwater elevations. In addition, groundwater elevations in these wells are monitored quarterly as part of the sentry well monitoring program. The deepest wells in the clusters adjacent to the NCMA urban area (wells 24B03, 30F03, and 30N02) are also screened at depths closely matching the screened

depths of most local pumping wells. Hence, measured water elevations in these deepest wells reflect the net effect of changing groundwater recharge and discharge conditions in the most-used aquifer zone.

Averaging the groundwater elevations from these three wells provides a single, representative index for tracking the status of the basin. Historical variation of this index is shown as the average deep sentry well elevations on Figure 12A. Figure 12A clearly shows three years of drought followed by recovery in this highly-developed aquifer zone. Specifically, the graph shows that this index has improved significantly since the 2008 Annual Report.

In order to measure potential short term water level fluctuations due to pumping, tidal fluctuation or other factors the NCMA group approved installation of pressure and electrical conductivity transducers in deepest wells at three of the sentry well locations (32S/12E-24B03; 32S/13E-30F03; and 32S/13E-30N02). In addition, a transducer was placed in well 32S/12E-24B01 to measure changes in water levels and salinity in the shallow groundwater that may be influenced by storms and other coastal processes. Since April 20, 2011 the measurement interval has been 30 minutes (Figures 12B through 12E).

Data from the continuous monitoring sensors shows water level changes of 0.2 to 1.6 ft in 6 hours with larger changes occurring in multi-day time frames. Water level changes exhibit timing that is similar to ocean tides measured in nearby Port San Luis. In the cases of 32S/12E-24B01, 32S/12E-24B03, and 32S/13E-30N02, fluctuations also reflect longer term variation in the tidal range.

Direct influence of the rainfall event of mid-March is apparent in the deeper sentry wells - 32S/12E-24B03, 32S/13E-30N02 and 32S/13E-30F03. Well 32S/13E-30F03 shows two periods of water level increases beginning in mid-August and early September. Wells 32S/12E-24B03 and 32S/13E-30N02 shows increases at the same time but with significantly less magnitude. Data from continuous monitors also shows three distinct periods of decline and recovery in wells 32S/12E-24B03, 32S/13E-30N02 and 32S/13E-30F03. Daily pumping records from the municipal water suppliers show a correlation between increased groundwater extraction and these changes. Detailed evaluation of the data may provide insight regarding general aquifer characteristics and response to variation in pumping rate at locations along the shoreline. Additional well data may allow more detailed analysis of this response in the future.

4.2.3 Water Quality

Water is used in several ways in the NCMA; each use requires a certain minimum water quality. Since contaminants from seawater intrusion or anthropogenic sources can potentially lower the quality of water in the basin, water quality is monitored at several locations in the NCMA. In the NCMA area, water quality data are available from dedicated monitoring wells, from water supply wells and from surface water. Four well clusters

located along the coast were originally installed by the California Department of Water Resources to monitor for seawater intrusion. Each of these “sentry wells” has two or three individual wells (piezometers) completed at different depths. In addition, the Oceano CSD observation well cluster (located near Highway 1 in Oceano) includes four individual piezometers. Water quality information from each of the sentry wells and the Oceano CSD monitoring wells is gathered quarterly. In addition to the monitoring wells, consolidated water quality information from the DPH for local municipal wells was reviewed.

4.2.3.1 Sentry Wells

Four separate monitoring events occurred in 2011, with each piezometer in the sentry wells and in the Oceano CSD well measured in January, April, July, and November 2011. During each event, the wells were all sampled in accordance with ASTM International Standard D4448-01. Water quality data from these events and available historical data from these wells are presented on Tables 6A and 6B. Beginning in October 2011, water quality samples were obtained directly from the pump used to evacuate each well. Since water quality trends are used to monitor for seawater intrusion, data collected in 2011 were added to previous data and the variation of selected constituents have been plotted against time. (Other geochemical plots are discussed below.) Figure 13 and Figure 14 are meant to show variation of chloride and TDS concentration, respectively, in 2011. Data contained in Table 6A shows a wide variation in water quality during the years 2009 through 2011. However, samples obtained in 2011 show less variation and general improvement in overall quality compared to 2009. Todd Engineers (2010) suggested the observed *variation in water quality data could be due to a number of factors including: variable permeability of geologic materials, potential mixing with seawater, ion exchange in clay-rich units, and variability in surface recharge sources, such as Arroyo Grande and Meadow Creeks*. Changes in groundwater demand and abundant rainfall may have contributed to the general improvement of groundwater quality in 2011. These factors are discussed in more detail in Section 5.

Most wells showed similar chemical quality to results from 2010. With the exception of shallow well 32S/12E-24B01, no wells showed evidence of higher TDS or Chloride which may be indicators of seawater intrusion. Several wells showed continued improvement of water quality compared to 2008, 2009 and 2010 monitoring results. Key observations are discussed below.

Table 6a: Northern Cities Sentry Well Water Quality Data Summary

Well	Construction	Top of Casing Elevation (feet NAVD)	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)	Potassium (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Bicarbonate (as CaCO3) (mg/L)	Sulfate (mg/L)	Nitrate (mg/L)	Total Kjeldahl Nitrogen (mg/L)	Boron (mg/L)	Fluoride (mg/L)	Iodide (mg/L)	Manganese (mg/L)	Bromide (mg/L)	Alkalinity, Total (as CaCO3) (mg/L)	Carbonate (as CaCO3) (mg/L)	Hydroxide (as CaCO3) (mg/L)	Specific Conductance (umhos/cm)	Iron (mg/L)	Bromide / Chloride Ratio	Chloride / Bromide Ratio	
32S/12E-24B01	Screened from 48-65' - 2-inch diameter	13.20																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88	2.50 10.70	1/11/2012 11/21/2011	5.72 5.80	7.86 7.78	2,750 2,740	1200 1200	520 410	30 25	140 130	140 120	400 380	170 200	<0.1 <0.3	4.0 2.3	0.18 0.13	0.1 <0.6	0.033 0.053	0.94 0.90	3.2 2.73	400 380	<10 <10	<10 <10	4,560 4,470	0.55 0.7	0.0027 0.0023	375 440	
	TOC elevation prior to renovation (Approximate)	10.7	7/26/2011 7/25/2011	6.38 NA	7.20 NA	NA 3,690	NA 1199.9	NA 530	NA 33	NA 140	NA 150	NA 380	NA 200.2	NA <0.05	NA 1.8	NA 0.14	NA <0.1	NA 0.053	NA 0.91	NA 3.281	NA 380	NA <5	NA <5	NA 4,900	NA 0.73	NA 0.0027	NA 366	
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88	2.50 10.70	4/20/2011 1/24/2011	6.40 5.78	7.18 7.42	2,810 2,380	1214 1100	500 370	27 24	140 110	130 120	400 380	216 180	<0.05 <0.15	1.7 1.8	0.24 0.16	0.18 <0.3	0.067 0.63	0.95 0.68	3.3 2.8	400 380	<2.0 <2.0	<2.0 <2.0	4,430 4,020	NA 0.89	0.0027 0.0025	368 393	
	TOC elevation prior to renovation (Approximate)	10.7	10/28/2010 10/21/2010	NA 6.37	NA 6.83	2,330 NA	960 NA	390 NA	25 NA	140 NA	140 NA	350 NA	160 NA	<0.1 NA	3.9 NA	0.15 NA	<0.1 NA	NA NA	0.75 NA	2.6 NA	350 NA	<10 NA	<10 NA	3,860 NA	1.3 NA	0.0027 NA	369 NA	
			7/27/2010	6.48	6.72	616	43	52.5	6.21	115	44.7	341	160	<0.10	2.9	0.063	<0.10	0.11	0.274	0.18	341	<1.0	<1.0	1,000	9.34	0.0042	239	
			4/27/2010	3.84	6.86	676	47	54.7	4.60	107	43.6	327	140	<0.10	0.98	0.0714	<0.10	<0.10	0.0458	0.18	327	<1.0	<1.0	990	4.06	0.0038	261	
			1/27/2010	3.13	7.57	694	55	56.2	6.80	123	43.2	340	150	0.40	1.7	0.12	<0.10	0.33	0.875	0.19	340	<1.0	<1.0	1,000	16.6	0.0035	289	
			10/19/2009	2.28	8.42	766	140	121	16.7	111	52.4	303	150	0.25	2.8	0.0959	0.11	<0.10	0.208	0.47	303	<1.0	<1.0	1,200	7.79	0.0034	298	
			8/20/2009	3.25	7.45	705	94	86.8	11.7	116	35.6	286	150	0.21	2.7	NA	<0.10	0.12	0.248	0.38	286	<1.0	<1.0	1,000	7.15	0.0040	247	
			5/12/2009	3.58	7.12	695	100	82.1	13.2	108	45	288	150	NA	NA	NA	0.11	NA	0.66	0.29	288	<1.0	<1.0	1,100	23.9	0.0029	345	
			3/26/1996	NA	NA	1,870	773	380	24.0	125	95	427	154	0.2	NA	0.27	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			6/9/1976	NA	NA	1,706	667	400	16.2	94	95	474	159	0.4	NA	0.12	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			1/17/1966	NA	NA	1,700	652	406	20.0	95	83	440	175	1	NA	0.07	0.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
32S/12E-24B02	Screened from 120-145' - 2-inch diameter	13.22																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88	2.52 10.70	1/11/2012 11/21/2011	5.47 5.69	8.11 7.89	650 640	33 32	46 39	4.6 3.9	110 93	32 29	300 290	150 150	<0.1 <0.05	1.3 <1	<0.1 0.064	0.21 <0.1	<0.02 <0.01	0.13 0.096	0.034 <0.1	300 290	<10 <10	<10 <10	950 930	1.7 0.32	0.0010 NA	971 NA	
	TOC elevation prior to renovation (Approximate)	10.7	7/26/2011 7/25/2011	6.51 NA	7.07 NA	NA 640	NA 36	NA NA	NA NA	NA NA	NA NA	NA 290	NA 165.3	NA <0.05	NA <1	NA <0.1	NA <0.01	NA NA	NA NA	NA <0.1	NA 290	NA <5	NA <5	NA 950	NA NA	NA NA	NA NA	
			4/20/2011	6.30	7.28	620	39	46	7.4	90	36	320	174	<0.05	<1	0.17	0.14	0.014	<0.005	<0.1	320	<2.0	<2.0	950	NA	NA	NA	
			1/24/2011	5.69	7.53	640	43	44	5.9	87	28	270	170	<0.05	<1.0	0.11	<0.1	0.14	0.085	<0.1	270	<2.0	<2.0	940	1.3	NA	NA	
			10/28/2010	NA	NA	650	43	50	4.5	110	35	270	160	<0.1	<1.0	0.12	<0.1	NA	0.085	<0.3	270	<10	<10	970	0.63	NA	NA	
			10/21/2010	6.79	6.43	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/27/2010	7.05	6.17	598	42	48.9	4.29	111	40.5	318	160	<0.10	1.3	0.0609	<0.10	0.11	0.106	0.15	318	<1.0	<1.0	980	2.84	0.0036	280	
			4/27/2010	4.34	6.36	668	46	52.7	4.73	111	43.2	349	150	<0.10	1.3	0.0666	<0.10	0.14	0.101	0.16	349	<1.0	<1.0	980	6.66	0.0035	288	
			1/27/2010	3.38	7.32	622	45	58.0	5.39	115	32.2	270	160	0.18	0.84	0.117	<0.10	0.14	0.209	0.16	270	<1.0	<1.0	920	3.49	0.0036	281	
			10/19/2009	2.26	8.44	600	49	59.1	5.12	112	30.1	281	160	<0.10	0.98	0.0776	0.14	<0.10	0.163	0.19	281	<1.0	<1.0	870	1.14	0.0039	258	
			8/20/2009	4.09	6.61	630	49	63.5	5.85	128	30.1	288	150	<0.10	0.98	NA	<0.10	<0.10	0.203	0.20	288	<1.0	<1.0	920	3.22	0.0041	245	
			5/12/2009	4.74	5.96	622	82	67.5	6.33	114	34.5	282	150	NA	NA	NA	0.11	NA	0.252	0.24	282	<1.0	<1.0	990	6.76	0.0029	342	
			3/26/1996	NA	NA	652	54	46	5	107	24	344	169	0.2	NA	0.1	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			6/9/1976	NA	NA	565	34	52	4	104	27	337	153	0.6	NA	0.02	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			1/17/1966	NA	NA	651	62	79	5	101	32	380	147	0	NA	0.05	0.3	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
32S/12E-24B03	Screened from 270-435' - 2-inch diameter	13.23																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88	2.53 10.70	1/12/2012 11/21/2011	2.15 2.93	11.43 10.65	660 660	46 43	48 41	3.2 3.7	92 91	36 34	300 310	150 150	<0.1 <0.05	<1 1.6	<0.1 0.046	0.35 <0.1	<0.02 0.014	0.0080 0.0090	<0.2 <0.1	300 310	<10 <10	<10 <10	1,000 970	0.15 0.12	NA NA	NA NA	
	TOC elevation prior to renovation (Approximate)	10.7	7/26/2011 7/25/2011	3.17 NA	10.41 NA	NA 650	NA 46.3	NA 50	NA 6.0	NA 98	NA 38	NA 310	NA 159.6	NA <0.05	NA <1	NA <0.1	NA <0.1	NA 0.011	NA 0.0100	NA <0.1	NA 310	NA <5	NA <5	NA 1,010	NA 0.21	NA NA	NA NA	
			4/20/2011	3.25	10.33	650	47	48	4.6	95	31	310	168	<0.05	<1	0.11	0.08	0.015	0.0080	<0.1	310	<2.0	<2.0	1,020	NA	NA	NA	
			1/24/2011	2.65	10.58	660	46	44	5.6	87	33	320	160	<0.05	<1.0	NA	<0.1	0.15	0.0096	<0.1	320	<2.0	<2.0	1,020	0.22	NA	NA	
			10/28/2010	NA	NA	660	44	48	3.8	110	39	315	50	<0.1	<1.0	0.089	<0.1	NA	0.0120	<0.3	315	<10	<10	1,020	0.55	NA	NA	
			10/21/2010	4.60	8.63	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/27/2010	4.54	8.69	610	44	51.4	8.34	112	41.6	328	160	<0.10	1.8	0.0533	<0.10	0.17	0.0602	0.16	328	<1.0	<1.0	1,000	6.7	0.0036	275	
			4/27/2010	1.43	9.27	666	45	53.2	4.84	118	44	357	150	<0.10	1.5	0.0636	<0.10	0.1	0.0519	0.17	357	<1.0	<1.0	980	9.71	0.0038	265	
			1/27/2010	0.94	9.76	672	48	56.4	5.40	119	43.4	336	150	<0.10	1.4	0.101	<0.10	0.15	0.140	0.15	336	<1.0	<1.0	1,000	5.18	0.0031	320	
			10/19/2009	0.81	9.89	622	40	55.1	3.93	110	42.6	342	160	<0.10	<0.50	0.0613	<0.10	0.13	0.0181	0.14	342	<1.0	<1.0	880	0.343	0.0035	286	
			8/19/2009	4.18	6.52	680	47	54.9	5.21	128	43.4	337	150	<0.10	2.2	NA	<0.10	0.66	0.182	0.15								

Table 6a: Northern Cities Sentry Well Water Quality Data Summary

Well	Construction	Top of Casing Elevation (feet NAVD)	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)	Potassium (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Bicarbonate (as CaCO3) (mg/L)	Sulfate (mg/L)	Nitrate (mg/L)	Total Kjeldahl Nitrogen (mg/L)	Boron (mg/L)	Fluoride (mg/L)	Iodide (mg/L)	Manganese (mg/L)	Bromide (mg/L)	Alkalinity, Total (as CaCO3) (mg/L)	Carbonate (as CaCO3) (mg/L)	Hydroxide (as CaCO3) (mg/L)	Specific Conductance (umhos/cm)	Iron (mg/L)	Bromide / Chloride Ratio	Chloride / Bromide Ratio	
32S/13E-30F01	Screened from 15'-30 and 40-55' - 1-inch diameter	23.30																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)	2.94 20.36 20.4	1/10/2012	13.80	9.36	460	67	61	2.0	35	17	81	120	11	<1	<0.1	0.12	<0.01	<0.005	<0.1	81	<10	<10	720	<0.1	NA	NA	
			11/21/2011	13.78	9.38	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			11/17/2011	NA	NA	470	70	82	2.40	40	19	78	120	12	<1	<0.1	<0.1	<0.01	<0.005	0.16	78	<10	<10	720	<0.1	0.0023	438	
			7/26/2011	13.50	9.66	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	460	65.8	68	4.40	37	19	78	117.4	12.17	<1	0.100	0.101	<0.01	0.014	0.178	78	<5	<5	720	0.11	0.0027	370	
			4/20/2011	12.82	10.34	460	71	69	2.60	36	14	87	124	12	<1	0.180	0.11	<0.01	<0.005	0.17	87	<2.0	<2.0	730	NA	0.0024	418	
			1/24/2011	13.33	9.97	510	75	64	4.00	34	18	83	140	11	<1.0	0.170	0.11	<0.10	<0.005	<0.1	83	<2.0	<2.0	780	<0.1	NA	NA	
			10/21/2010	16.55	6.75	540	100	73	2.00	43	21	88	120	13	<1.0	0.067	<0.1	NA	<0.005	<0.3	88	<10	<10	894	<1	NA	NA	
			7/26/2010	15.68	7.62	464	74	82.2	2.16	47.9	25.1	88.0	120	12	< 0.50	0.098	< 0.10	< 0.10	0.0817	0.37	88.0	< 1.0	< 1.0	710	0.79	0.0050	200	
			4/27/2010	11.02	9.38	534	72	77.1	2.59	45.8	23.6	100	140	9.8	0.56	0.129	< 0.10	< 0.10	0.112	0.29	100	< 1.0	< 1.0	780	1.02	0.0040	248	
			1/28/2010	12.73	7.67	725	140	99.9	2.70	76.4	35.8	214	170	1.6	0.84	0.120	< 0.10	< 0.10	0.112	0.56	214	< 1.0	< 1.0	1,200	0.640	0.0040	250	
			10/19/2009	14.33	6.07	522	74	85.6	2.35	52.8	26.3	102	150	13	0.70	0.136	0.13	< 0.10	0.123	0.32	102	< 1.0	< 1.0	770	1.30	0.0043	231	
			8/19/2009	14.34	6.06	648	92	98.9	3.84	63.1	31.9	113	190	10	0.56	NA	< 0.10	0.12	1.03	0.32	113	< 1.0	< 1.0	970	4.52	0.0035	288	
			5/12/2009	12.38	8.02	792	110	108	2.89	80.2	39.9	136	280	NA	NA	NA	< 0.10	NA	0.0353	0.39	136	< 1.0	< 1.0	1,200	0.281	0.0035	282	
32S/13E-30F02	Screened from 75-100' - 2-inch diameter	23.29																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)	2.93 20.36 20.4	1/12/2012	14.31	8.85	610	52	45	3.0	73	32	200	130	12	<1	<0.1	0.25	<0.02	0.29	0.33	200	<10	<10	890	<0.1	0.0063	158	
			11/21/2011	14.94	8.22	580	49	38	2.7	73	30	190	120	13	<1	0.07	<0.1	<0.01	0.022	0.34	190	<10	<10	870	<0.1	0.0069	144	
			7/26/2011	14.46	8.7	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	590	52.1	46	5.1	73	31	190	134.3	13.19	<1	<0.1	0.127	<0.1	0.025	0.387	190	<5	<5	900	<0.1	0.0074	135	
			4/20/2011	14.23	8.93	600	54	57	4.2	74	29	200	141	13	<1	0.18	0.17	<0.01	0.025	0.38	200	<2.0	<2.0	920	NA	0.0070	142	
			1/24/2011	14.36	8.93	600	51	43	4.9	71	31	210	140	12	<1.0	0.15	0.12	0.27	0.041	0.3	210	<2.0	<2.0	920	<0.1	0.0059	170	
			10/28/2010	NA	NA	610	49	38	2.3	70	30	210	130	11	<1.0	0.10	<0.1	NA	0.0094	<0.3	210	<10	<10	920	<0.1	NA	NA	
			10/21/2010	7.39	15.9	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/26/2010	16.21	7.08	560	49	45.8	2.95	85.4	36.8	223	130	11	2.5	0.0928	< 0.10	0.13	0.0646	0.59	223	< 1.0	< 1.0	890	< 0.100	0.0120	83	
			4/27/2010	12.14	8.26	634	51	50.3	3.12	87.9	38.6	225	130	10	0.8	0.112	< 0.10	< 0.10	0.615	0.51	225	< 1.0	< 1.0	880	3.28	0.0100	100	
			1/28/2010	13.09	7.31	604	44	52.2	4.47	92.1	38.5	230	150	11	1.4	0.127	< 0.10	< 0.10	0.913	0.48	230	< 1.0	< 1.0	920	4.55	0.0109	92	
			10/19/2009	14.36	6.04	566	49	49.5	2.80	88.3	37.6	240	140	11	1.0	0.0942	0.17	< 0.10	0.924	0.51	240	< 1.0	< 1.0	850	2.15	0.0104	96	
			8/19/2009	14.81	5.59	614	49	51.8	3.19	87.3	36.8	225	130	11	2.00	NA	0.10	< 0.10	2.24	0.54	225	< 1.0	< 1.0	920	19.4	0.0110	91	
			5/12/2009	14.34	2.96	514	54	48.7	3.26	81.1	34.9	206	120	NA	NA	NA	0.11	NA	1.87	0.53	206	< 1.0	< 1.0	890	3.23	0.0098	102	
			3/27/1996	NA	NA	678	49	52	3.8	98	42	305	166	49	NA	0.16	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			6/9/1976	NA	NA	637	48	55	2.8	98	43	343	172	17.6	NA	0.1	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			1/20/1966	NA	NA	580	68	47	2	94	38	280	152	27	NA	0.08	0.2	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
32S/13E-30F03	Screened from 305-372' - 2-inch diameter	23.31																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)	2.95 20.36 20.4	1/12/2012	12.37	10.79	660	46	39	2.1	94	42	280	160	<0.1	<1	<0.1	0.2	0.025	0.016	<0.2	280	<10	<10	990	<0.1	NA	NA	
			11/21/2011	13.24	9.92	650	43	33	2.6	93	39	290	160	<0.05	<1	0.036	0.15	0.028	0.016	<0.1	290	<10	<10	960	<0.1	NA	NA	
			7/26/2011	14.22	8.94	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	650	46.5	46	5.1	73	31	190	170.5	<0.05	<1	<0.1	0.155	0.02	0.025	<0.1	190	<5	<5	900	<0.1	NA	NA	
			4/21/2011	NA	NA	650	48	40	3.8	91	34	280	179	<0.05	<1	0.1	0.2	0.029	0.015	0.11	280	<2.0	<2.0	1,000	NA	0.0023	436	
			4/20/2011	12.51	10.65	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			1/24/2011	12.67	10.64	650	46	36	4.7	87	38	300	170	<0.05	<1.0	0.11	0.17	0.24	0.016	<0.1	300	<2.0	<2.0	990	<0.1	NA	NA	
			10/28/2010	NA	NA	650	46	37	2.7	100	43	280	160	<0.1	<1.0	0.10	<0.1	NA	0.032	<0.3	280	<10	<10	1,000	0.53	NA	NA	
			10/21/2010	6.62	16.69	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/26/2010	17.32	5.99	608	45	43.8	2.94	107	46.8	294	160	1.3	0.84	0.0479	< 0.10	0.10	0.129	0.24	294	< 1.0	< 1.0	900	7.55	0.0053	188	
			4/27/2010	11.38	9.02	668	48	40.8	2.91	101	44.7	304	160	0.21	0.84	0.0733	0.14	0.11	0.0694	0.23	304	< 1.0	< 1.0	940	2.62	0.0048	209	
			1/28/2010	10.98	9.42	656	40	43.1	3.91	112	47.2	310	180	< 0.20	2.8	0.0833	0.13	< 0.10	0.287	0.21	310	< 1.0	< 1.0	980	4.80	0.0053	190	
	</																											

Table 6a: Northern Cities Sentry Well Water Quality Data Summary

Well	Construction	Top of Casing Elevation (feet NAVD)	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)	Potassium (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Bicarbonate (as CaCO3) (mg/L)	Sulfate (mg/L)	Nitrate (mg/L)	Total Kjeldahl Nitrogen (mg/L)	Boron (mg/L)	Fluoride (mg/L)	Iodide (mg/L)	Manganese (mg/L)	Bromide (mg/L)	Alkalinity, Total (as CaCO3) (mg/L)	Carbonate (as CaCO3) (mg/L)	Hydroxide (as CaCO3) (mg/L)	Specific Conductance (umhos/cm)	Iron (mg/L)	Bromide / Chloride Ratio	Chloride / Bromide Ratio		
32S/13E-30N01	Screened from 15-40' - 1-inch diameter	15.53																											
Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)		2.00 13.53 13.5	1/9/2012	8.74	7.39	1,050	260	170	34	68	52	307	200	<0.05	2.7	0.21	0.41	<0.01	0.088	1.9	307	<10	<10	1,760	2.9	0.0073	137		
			11/21/2011	8.78	7.35	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			11/17/2011	NA	NA	1,300	360	320	40	90	69	390	220	<0.1	<1	0.23	0.38	0.017	0.11	2.5	390	<10	<10	2,210	3.4	0.0069	144		
			7/26/2011	9.01	7.12	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	1,680	445.3	230	42	99	81	380	255.5	<0.05	1.2	0.21	<0.1	0.12	3.016	380	<5	<5	2,480	4.2	0.0068	148			
			4/20/2011	8.59	7.54	890	210	130	26	68	46	180	215	<0.05	<1	0.24	0.39	0.013	0.086	4.57	180	<2.0	<2.0	1,550	NA	0.0218	46		
			1/24/2011	8.18	7.35	870	180	100	28	84	46	240	210	<0.05	<1.0	<0.1	0.34	0.12	0.24	3.63	240	<2.0	<2.0	1,430	18	0.0202	50		
			10/21/2010	9.99	5.54	890	190	120	26	58	45	246	200	<0.1	<1.0	<0.1	0.37	NA	0.078	2.3	246	<1.0	<1.0	1,498	<0.1	0.0121	83		
			7/27/2010	8.97	6.56	917	200	130	30.0	75.0	56.2	241	220	<0.10	<0.50	0.165	0.29	0.23	0.101	2.8	241	<1.0	<1.0	1,400	2.61	0.0140	71		
			4/27/2010	6.14	7.36	808	150	130	29	136	55.6	286	210	0.76	1.7	0.171	0.37	0.19	0.276	2.6	286	<1.0	<1.0	1,300	20.4	0.0173	58		
			1/26/2010	4.90	8.60	902	210	155	33.5	156	66.4	307	230	<0.10	1.7	0.317	0.30	0.12	0.333	3.2	307	<1.0	<1.0	1,500	27.3	0.0152	66		
			10/20/2009	6.53	7.00	828	200	159	34.3	118	59.8	238	230	<0.10	1.3	0.241	0.38	<0.10	0.157	3.2	238	<1.0	<1.0	1,300	5.33	0.0160	63		
			8/20/2009	6.71	6.82	835	160	150	27.8	121	49.4	235	220	<0.10	1.3	NA	0.37	0.12	0.228	2.9	235	<1.0	<1.0	1,400	15.9	0.0181	55		
			5/11/2009	6.03	7.50	960	180	175	33.5	86.7	46.2	274	220	NA	NA	NA	NA	0.36	NA	0.113	3.2	274	<1.0	<1.0	1,500	2.26	0.0178	56	
			32S/13E-30N03	Screened from 60-135' - 2-inch diameter	15.43																								
Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)		1.90 13.53 13.5	1/11/2012	7.17	8.96	570	67	55	3.9	68	30	140	130	14	<1	0.1	0.22	<0.02	0.051	0.39	140	<10	<10	870	0.17	0.0058	172		
			11/21/2011	6.45	9.68	600	67	47	3.2	64	28	140	130	15	1.2	0.088	0.2	<0.01	<0.005	0.62	140	<10	<10	850	<0.1	0.0093	108		
			7/26/2011	7.59	8.54	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	590	67	47	5.0	54	24	290	139.8	15	<1	<0.1	0.2	<0.01	0.0520	0.79	290	<5	<5	890	0.14	0.0118	85		
			4/20/2011	6.65	9.48	580	76	58	4.2	62	23	140	142	16	<1	0.12	0.2	<0.1	0.0510	0.92	140	<2.0	<2.0	890	NA	0.0121	83		
			1/24/2010	6.68	8.75	570	76	48	4.8	55	25	130	130	16	<1.0	0.12	0.2	<0.10	0.0088	1.7	130	<2.0	<2.0	900	<0.1	0.0224	45		
			10/21/2010	10.76	4.67	550	69	59	3.3	65	31	133	130	15	<1.0	<0.1	0.1	NA	<0.005	1.1	133	<1.0	<1.0	886	<0.1	0.0159	63		
			7/27/2010	9.53	5.90	528	72	55.1	3.41	68.7	31.0	139	130	15.0	<0.50	0.0672	0.14	0.11	<0.00500	1.3	139	<1.0	<1.0	860	<0.100	0.0181	55		
			4/27/2010	6.14	7.36	672	89	60.6	3.65	70.6	32.5	134	130	14.0	<0.50	0.0779	0.18	0.11	<0.00500	1.2	134	<1.0	<1.0	870	<0.100	0.0135	74		
			1/26/2010	5.88	7.62	606	110	75.0	4.51	77.8	34.3	126	130	14	1.4	0.0654	0.15	<0.10	0.0130	1.3	126	<1.0	<1.0	990	0.653	0.0118	85		
			10/20/2009	6.56	6.94	806	180	93.3	25.5	92.3	41.5	162	150	9.7	2.2	0.107	0.26	<0.10	0.245	1.4	162	<1.0	<1.0	1,200	0.344	0.0078	129		
			8/20/2009	7.50	6.00	1,070	190	151	61.6	112	44.2	130	130	16	3.4	NA	0.20	<0.10	0.151	1.6	130	<1.0	<1.0	1,700	1.93	0.0084	119		
			5/12/2009	6.33	7.17	602	97	63.4	3.96	72.9	32.2	122	120	NA	NA	NA	0.22	NA	24	1.2	122	<1.0	<1.0	900	2.24	0.0124	81		
			3/27/1996	NA	NA	624	70	62	4	78	35	150	161	106.8	NA	0.13	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			6/7/1976	NA	NA	705	90	54	2.9	99	43	189	168	112.5	NA	0.08	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
1/21/1966	NA	NA	804	57	54	3	132	59	410	250	1	NA	0.08	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA			
32S/13E-30N02	Screened from 175-255' - 2-inch diameter	15.43																											
Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate) Confirmation Sample Collected from Pump Discharge at End of Purge: Confirmation Sample Collected by Standard Method (Bailer):		1.90 13.53 13.5	1/11/2012	4.88	11.25	1,040	49	64	4.9	130	54	180	460	1.30	<1	0.17	0.16	<0.02	<0.005	<0.2	180	<10	<10	1,360	<0.1	NA	NA		
			11/21/2011	5.35	10.78	1,020	46	57	4.5	130	54	180	450	0.15	<1	0.15	<0.2	<0.01	<0.005	<0.2	180	<10	<10	1,360	<0.1	NA	NA		
			7/26/2011	7.25	8.88	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	1,050	50.4	81	7.7	150	62	180	479.1	0.15	<1	0.16	0.144	<0.01	0.006	<0.1	180	<5	<5	1,370	0.49	NA	NA		
			4/20/2011	3.53	12.60	1,030	52	63	5.4	130	44	180	508	0.17	<1	0.19	0.2	<0.01	<0.005	<0.1	180	<2.0	<2.0	1,380	NA	NA	NA		
			1/24/2011	3.67	11.76	1,050	50	60	6.4	120	49	190	490	0.24	<1.0	0.17	0.17	<0.10	0.064	<0.1	190	<2.0	<2.0	1,380	0.12	NA	NA		
			10/21/2010	10.42	5.01	1,040	48	52	3.5	100	45	181	460	0.15	<1.0	<0.1	<0.1	NA	<0.005	<0.3	181	<1.0	<1.0	1,377	<0.1	NA	NA		
			7/27/2010	10.02	5.41	777	57	67.6	7.31	141	58.5	190	470	0.3	3.5	0.138	<0.10	0.11	0.102	0.28	190	<1.0	<1.0	1,300	3.43	0.0049	204		
			4/27/2010	5.26	8.27	800	93	71.9	12.50	108	46.3	159	300	7.0	3.2	0.123	0.13	0.11	0.0776	0.7	159	<1.0	<1.0	1,100	3.27	0.0075	133		
			2/25/2010	1.72	11.78	1,000	48	71.4	4.70	141	58.1	195	490	0.16	<0.50	0.15	0.15	<0.10	0.0393	0.16	195	<1.0	<1.0	1,300	3.30	0.0033	300		
			2/25/2010	1.72	11.78	1,010	74	76.9	10.2	138	55.8	195	440	0.13	2.4	0.142	0.16	<0.10	0.0579	0.24	195	<1.0	<1.0	1,400	1.69	0.0032	308		
			1/26/2010	3.72	9.78	970	50	74.2	4.77	152	62.2	195	510	0.14	<0.50	0.129	0.11	<0.10	<0.00500	0.16	195	<1.0	<1.0	1,300	<0.100	0.0032	313		
			10/20/2009	7.38	6.12	2,080	690	274	151	239	101.0	220	400	<0.10	7.0	0.201	0.16	0.87	0.398	2.0	220	<1.0	<1.0	2,800	5.50	0.0029	345		
			8/20/2009	11.94	1.56	1,350	500	199	82.2	123	49.0	199	220	6.4	6.3	NA	0.23	0.14	0.339	2.8	199	<1.0	<1.0	2,100	4.91	0.0056	179		
			5/11/2009	6.98	6.52	1,290	170																						

Table 6a: Northern Cities Sentry Well Water Quality Data Summary

Well	Construction	Top of Casing Elevation (feet NAVD)	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)	Potassium (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Bicarbonate (as CaCO3) (mg/L)	Sulfate (mg/L)	Nitrate (mg/L)	Total Kjeldahl Nitrogen (mg/L)	Boron (mg/L)	Fluoride (mg/L)	Iodide (mg/L)	Manganese (mg/L)	Bromide (mg/L)	Alkalinity, Total (as CaCO3) (mg/L)	Carbonate (as CaCO3) (mg/L)	Hydroxide (as CaCO3) (mg/L)	Specific Conductance (umhos/cm)	Iron (mg/L)	Bromide / Chloride Ratio	Chloride / Bromide Ratio	
12N/36W-36L01	Screened from 227-237' - 2-inch diameter	26.29																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)	2.31 23.98 24.0	1/11/2012	17.68	9.09	790	41	64	4.1	120	44	170	380	1.30	<1	0.19	0.18	<0.02	<0.005	<0.2	170	<10	<10	1,190	<0.1	NA	NA	
			11/21/2011	18.08	8.69	910	39	55	3.5	110	40	180	380	0.37	<1	0.16	<0.2	<0.01	<0.005	<0.2	180	<10	<10	1,200	<0.1	NA	NA	
			7/26/2011	19.63	7.14	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	890	40.5	65	5.7	110	43	170	408.9	0.39	<1	0.15	<0.1	<0.01	<0.005	<0.1	170	<5	<5	1,200	0.024	NA	NA	
			4/21/2011	NA	NA	890	42	61	4.2	100	30	170	415	0.60	<1	0.19	0.07	<0.01	<0.005	<0.1	170	<2.0	<2.0	1,200	NA	NA	NA	
			4/20/2011	18.26	8.51	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			1/24/2011	17.61	8.68	890	41	55	5.1	98	36	180	400	0.50	<1.0	0.20	0.15	<0.10	<0.005	<0.1	180	<2.0	<2.0	1,200	<0.1	NA	NA	
			10/21/2010	20.75	5.54	910	38	76	3.6	130	47	169	400	0.39	<1.0	0.10	<0.1	NA	<0.005	<0.3	169	<10	<10	1,213	<0.1	NA	NA	
			7/27/2010	21.18	5.11	707	36	64.2	3.70	127	47.4	182	420	0.40	< 0.50	0.158	< 0.10	< 0.10	< 0.00500	0.11	182	< 1.0	< 1.0	1,100	< 0.100	0.0031	327	
			4/26/2010	15.94	8.06	860	42	70.3	4.13	129	48.9	191	400	0.45	0.77	0.223	< 0.1	0.15	0.057	0.14	191	< 1.0	< 1.0	1,100	4.53	0.0033	300	
			10/21/2009	17.72	6.28	856	38	72.0	4.64	131	48.2	192	420	0.49	0.84	0.150	0.12	< 0.10	0.0994	0.13	192	< 1.0	< 1.0	1,100	1.68	0.0034	292	
			8/20/2009	19.16	4.84	890	39	78.0	4.21	138	48.1	184	390	0.49	0.56	NA	< 0.10	< 0.10	0.185	0.14	184	< 1.0	< 1.0	1,200	2.03	0.0036	279	
			5/11/2009	17.68	6.32	832	63	83.8	4.88	111	45.4	204	330	NA	NA	NA	0.12	NA	0.551	0.22	204	< 1.0	< 1.0	1,200	4.02	0.0035	286	
			3/26/1996	NA	NA	882	35	66	4.8	124	47	233	408	2	NA	0.24	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			6/8/1976	NA	NA	936	38	72	3.5	130	48	223	423	0.6	NA	0.15	0.7	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
12N/36W-36L02	Screened from 535-545' - 2-inch diameter	26.29																										
	Wellhead renovation in 6/2010 added to the TOC elevation Pad elevation NAVD 88 TOC elevation prior to renovation (Approximate)	2.31 23.98 24.0	1/11/2012	11.18	15.59	900	122	110	7.2	95	37	290	170	<0.1	4.8	0.48	0.28	<0.02	0.170	0.45	290	<10	<10	1,250	1.80	0.0037	271	
			11/21/2011	13.99	12.78	780	130	95	6.1	77	33	270	160	<0.1	<1	0.4	<0.2	<0.01	0.130	0.45	270	<10	<10	1,240	0.40	0.0035	289	
			7/26/2011	18.03	8.74	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			7/25/2011	NA	NA	790	128.8	110	9.1	74	33	280	177	<0.05	2.3	0.36	0.12	0.14	0.130	0.51	280	<5	<5	1,280	2.30	0.0040	252	
			4/21/2011	NA	NA	770	120	90	5.3	86	26	280	206	<0.05	2.3	0.24	0.26	0.14	0.004	0.57	280	<2.0	<2.0	1,270	NA	0.0048	211	
			4/20/2011	10.33	16.44	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			1/24/2011	9.37	16.92	800	120	95	7.6	75	30	300	190	<0.05	2.3	0.39	0.16	1.31	0.13	0.53	300	<2.0	<2.0	1,270	1.40	0.0044	226	
			10/21/2010	19.77	6.52	770	120	130	7.6	89	44	275	160	<0.1	3.4	0.48	<0.1	NA	0.15	0.54	275	<10	<10	1,293	0.12	0.0045	222	
			7/27/2010	20.53	5.76	737	110	121	7.81	91.1	38.9	268	190	< 0.10	< 0.50	0.427	0.10	0.77	0.180	0.80	268	< 1.0	< 1.0	1,200	0.845	0.0073	138	
			4/26/2010	9.24	14.76	720	100	116	6.88	85.4	32.4	215	210	1.5	0.77	0.382	0.2	0.28	0.167	0.7	215	< 1.0	< 1.0	1,100	3.870	0.0070	143	
			10/21/2009	17.65	6.35	638	99	113	6.15	81.6	23.0	172	200	< 0.10	3.2	0.268	0.33	57	0.128	0.61	172	< 1.0	< 1.0	940	0.255	0.0062	162	
			8/20/2009	19.15	4.85	785	100	131	6.66	89.8	36.6	290	190	< 0.10	3.8	NA	0.15	0.27	0.307	0.75	290	< 1.0	< 1.0	1,200	0.830	0.0075	133	
			5/11/2009	14.38	9.62	775	120	132	7.24	84	39.7	294	180	NA	NA	NA	0.18	NA	0.426	0.78	294	< 1.0	< 1.0	1,300	0.958	0.0065	154	
			3/26/1996	NA	NA	772	127	130	8.7	86	36	390	148	0.2	NA	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
			6/8/1976	NA	NA	820	126	118	6.6	94	44	393	184	0	NA	NA	0.5	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA

Table 6a: Northern Cities Sentry Well Water Quality Data Summary

Well	Construction	Top of Casing Elevation (feet NAVD)	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)	Potassium (mg/L)	Calcium (mg/L)	Magnesium (mg/L)	Bicarbonate (as CaCO3) (mg/L)	Sulfate (mg/L)	Nitrate (mg/L)	Total Kjeldahl Nitrogen (mg/L)	Boron (mg/L)	Fluoride (mg/L)	Iodide (mg/L)	Manganese (mg/L)	Bromide (mg/L)	Alkalinity, Total (as CaCO3) (mg/L)	Carbonate (as CaCO3) (mg/L)	Hydroxide (as CaCO3) (mg/L)	Specific Conductance (umhos/cm)	Iron (mg/L)	Bromide / Chloride Ratio	Chloride / Bromide Ratio		
Oceano MW-Green	Screened from 110-130' - 3-inch diameter	30.86																											
			Casing relative to concrete pad	-4.14	1/12/2012	23.29	11.34	760	76	85	4.00	79	40	270	190	<0.1	<1	0.23	0.21	0.069	0.23	<0.2	270	<10	<10	1,150	4.8	NA	NA
	All elevations relative to MSL	Pad elevation above MSL, approximate	35.0	11/21/2011	22.46	12.17	720	39	38	3.40	96	43	320	180	<0.05	3.5	0.079	0.19	0.013	0.17	<0.1	320	<10	<10	1,050	4.8	NA	NA	
		7/26/2011	25.51	9.12	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		7/25/2011	NA	NA	760	69.3	66	6.40	80	35	310	208.8	<0.05	<1	0.16	0.17	0.041	0.23	0.199	310	<5	<5	1,170	5.3	0.0029	348			
		4/20/2011	114.79	-80.16	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		1/24/2011	106.59	-71.96	310	98	22	8.1	34	9.2	19.0	53	<0.05	<1.0	<0.1	0.2	4.42	0.4	0.63	19.0	<2.0	<2.0	480	10	0.0064	156			
		10/28/2010	NA	NA	290	81	26	9.3	64	11	160.0	68	<0.1	<1.0	<0.1	0.2	NA	0.85	0.36	160.0	<10	<10	520	38	0.0044	225			
		10/21/2010	112.71	-81.85	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		7/26/2010	95.61	-64.75	438	85	34.3	1.93	61.7	30.4	30.0	210	< 0.10	< 0.50	0.0435	0.58	0.22	1.46	0.32	30.0	< 1.0	< 1.0	690	36	0.0038	266			
		4/26/2010	63.90	-33.04	560	83	47.7	5.7	86.1	48.3	62	310	< 0.10	0.84	< 0.02	< 0.1	0.56	2.54	0.31	62.0	< 1.0	< 1.0	880	233	0.0037	268			
		1/27/2010	43.71	-12.85	460	130	45.0	25.4	682	124	112	100	0.56	NA	< 0.0200	0.21	0.25	32.4	0.49	112.0	< 1.0	< 1.0	760	4,360	0.0038	265			
		10/20/2009	29.20	1.66	362	92	39.6	2.92	19.2	45.1	76.8	110	< 0.10	< 0.50	0.0697	< 0.10	< 0.10	0.242	0.39	80.0	3.2	< 1.0	590	11.4	0.0042	236			
8/19/2009	24.55	6.31	420	160	48.4	3.37	49.9	20.4	17.6	54	< 0.10	1.1	NA	< 0.10	0.25	1.76	0.68	17.6	< 1.0	< 1.0	690	242	0.0043	235					
5/16/1983	15.80	15.06	665	35	40	NA	85	65	360	90	< 4	NA	NA	0.2	NA	0.01	NA	360	ND	ND	950	0.10	NA	NA					
Oceano MW-Blue	Screened from 190-210' and 245-265' - 3-inch diameter	30.91																											
			Casing relative to concrete pad	-4.09	1/12/2012	22.26	12.37	480	96	110	4.9	5.6	33	154	95	<0.1	<1	0.28	<0.2	0.11	0.01	0.306	180	26	<10	850	0.19	0.0032	314
	All elevations relative to MSL	Pad elevation above MSL, approximate	35.0	11/21/2011	22.73	11.90	390	90	78	4.6	5.2	24	111	86	<0.05	<1	0.19	0.13	0.092	0.014	0.28	128	17	<10	720	0.5	0.0031	321	
		7/26/2011	25.29	9.34	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		7/25/2011	NA	NA	260	29.3	23	5.3	8.7	20	84	80	<0.05	<1	<0.1	0.199	0.072	0.041	<0.1	89	<5	<5	440	2.7	NA	NA			
		4/21/2011	NA	NA	580	118	70	19	49	17	8.8	274	<0.05	<1	<0.1	0.29	0.109	0.091	0.4	11.3	2.5	<2.0	950	NA	0.0034	295			
		4/20/2011	22.59	12.04	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		1/24/2011	24.87	9.76	680	110	60	17	64	22	5.0	330	<0.05	<1.0	<0.1	0.22	0.96	0.16	0.31	11.2	6.2	<2.0	1,040	10.0	0.0028	355			
		10/21/2010	30.11	0.80	770	100	68	12	88	31	14.0	380	<0.1	<1.0	<0.1	0.28	NA	0.054	<0.3	14.0	<10	<10	1,163	2.2	NA	NA			
		7/26/2010	24.74	6.17	783	130	80.1	8.58	142	42.0	2.8	450	< 0.10	< 0.50	< 0.0200	0.26	0.31	3.97	0.8	2.8	< 1.0	< 1.0	1,200	593	0.0059	169			
		4/26/2010	18.52	12.39	1,130	160	70.2	6.48	208	50.7	8.4	530	< 0.10	0.56	< 0.02	0.23	0.54	3.10	1.0	8.4	< 1.0	< 1.0	1,600	383	0.0061	165			
		1/27/2010	22.06	8.85	1,740	430	55.6	4.98	282	43.0	< 1.0	680	< 0.10	< 0.50	0.0819	0.14	0.41	9.41	2.0	< 1.0	< 1.0	2,300	170	0.0047	215				
		10/20/2009	27.50	3.41	2,250	1,000	19.5	2.40	487	22.5	5.0	410	< 0.10	0.98	0.0532	0.13	< 0.10	13.1	4.5	5.0	< 1.0	< 1.0	3,100	236	0.0045	222			
8/19/2009	24.65	6.26	322	150	93.2	16.7	23.9	12.1	3.0	4.0	< 0.10	1.3	NA	0.19	0.5	0.7	0.74	23.0	20.0	< 1.0	640	153	0.0049	203					
5/16/1983	13.30	17.61	840	80	90	NA	100	50	250	160.0	< 4	NA	ND	0.2	NA	0.14	NA	250.0	ND	ND	1,200	0.10	NA	NA					
Oceano MW-Silver	Screened from 395-435' and 470-510' - 3-inch diameter	30.85																											
			Casing relative to concrete pad	-4.15	11/21/2011	23.00	11.63	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
	All elevations relative to MSL	Pad elevation above MSL, approximate	35.0	7/26/2011	25.23	9.4	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
		4/21/2011	NA	NA	410	97	100	7.2	3.5	21	80	134	<0.05	<1	0.23	0.18	0.097	0.065	0.42	100	20	<2.0	770	NA	0.0043	231			
		4/20/2011	21.27	13.36	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		1/24/2011	22.02	12.61	440	92	90	9.2	3.4	27	90	140	<0.05	<1.0	0.25	0.11	0.94	0.041	0.35	110	20	<2.0	810	2.2	0.0038	263			
		10/21/2010	29.11	1.74	460	90	110	15	6.8	32	94	140	<0.1	<1.0	0.2	0.1	NA	0.1	0.38	124	30	<10	868	3.5	0.0042	237			
		7/26/2010	24.24	6.61	478	83	109	5.94	52.9	30.4	122.0	94	< 0.10	<0.50	0.255	< 0.10	0.41	0.477	0.56	130.0	8.0	< 1.0	730	61.0	0.0067	148			
		4/26/2010	19.04	11.81	452	83	83	7.42	29.3	34.5	72.0	190	< 0.1	0.56	0.134	< 0.10	0.65	0.702	0.4	86.0	14.0	< 1.0	810	71.0	0.0048	208			
		1/27/2010	21.05	9.8	496	71	92.2	10.6	22.9	39.1	13.0	230	<0.10	< 0.50	0.323	< 0.10	0.20	0.604	0.29	51.0	38.0	< 1.0	780	54.4	0.0041	245			
		10/20/2009	27.52	3.33	564	71	80.8	8.63	33.2	49.8	49.6	310	<0.10	< 0.50	0.148	< 0.10	< 0.10	0.337	0.32	64.0	14.4	< 1.0	850	20.0	0.0045	222			
		8/19/2009	29.34	1.51	522	180	148	71.6	95.2	8.42	30.0	3.5	<0.10	1.7	NA	0.24	0.52	2.36	0.76	170	140	< 1.0	1,000	278	0.0042	237			
		5/16/1983	13.50	17.35	630	40	40	NA	90	50	330	80	< 4	NA	NA	0.1	NA	0.02	NA	330	ND	ND	900	0.05	NA	NA			
Oceano MW-Yellow	Screened from 625-645' - 3-inch diameter	30.89																											
			Casing relative to concrete pad	-4.11	1/12/2012	23.08	11.55	410	94	95	4.5	3.0	28	300	68	<0.1	<1	0.24	<0.2	0.1	0.032	0.31	320	20	<10	760	0.89	0.0033	303
	All elevations relative to MSL	Pad elevation above MSL, approximate	35.0	11/21/2011	22.98	11.65	410	94	83	4.6	3.4	30	152	72	<0.05	<1	0.21	<0.1	0.09	0.035	0.3	160	8	<10	730	0.65	0.0032	313	
		7/26/2011	26.73	7.90	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
		7/25/2011	NA	NA	420	89.7	84	7.1	4.4	31	148	91.8	<0.05	<1	0.20	<0.1	0.071	0.046	0.297	150	2.5	<5	760	1.90	0.0033	302			

Table 6b: Northern Cities Sentry Well Water Quality Data Summary

Well	Production Interval	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)
32S/12E-24B01	Screened from 48-65'	1/11/2012	5.72	7.86	2,750	1200	520
		11/21/2011	5.80	7.78	2,740	1200	410
		7/26/2011	6.38	7.20	NA	NA	NA
		7/25/2011	NA	NA	3,690	1199.9	530
		4/20/2011	6.40	7.18	2,810	1214	500
		1/24/2011	5.78	7.42	2,380	1100	370
		10/28/2010	NA	NA	2,330	960	390
		10/21/2010	6.37	6.83	NA	NA	NA
		7/27/2010	6.48	6.72	616	43	52.5
		4/27/2010	3.84	6.86	676	47	54.7
		1/27/2010	3.13	7.57	694	55	56.2
		10/19/2009	2.28	8.42	766	140	121
		8/20/2009	3.25	7.45	705	94	86.8
		5/12/2009	3.58	7.12	695	100	82.1
		3/26/1996	NA	NA	1,870	773	380
6/9/1976	NA	NA	1,706	667	400		
1/17/1966	NA	NA	1,700	652	406		
32S/12E-24B02	Screened from 120-145'	1/11/2012	5.47	8.11	650	33	46
		11/21/2011	5.69	7.89	640	32	39
		7/26/2011	6.51	7.07	NA	NA	NA
		7/25/2011	NA	NA	640	36	NA
		4/20/2011	6.30	7.28	620	39	46
		1/24/2011	5.69	7.53	640	43	44
		10/28/2010	NA	NA	650	43	50
		10/21/2010	6.79	6.43	NA	NA	NA
		7/27/2010	7.05	6.17	598	42	48.9
		4/27/2010	4.34	6.36	668	46	52.7
		1/27/2010	3.38	7.32	622	45	58.0
		10/19/2009	2.26	8.44	600	49	59.1
		8/20/2009	4.09	6.61	630	49	63.5
		5/12/2009	4.74	5.96	622	82	67.5
		3/26/1996	NA	NA	652	54	46
6/9/1976	NA	NA	565	34	52		
1/17/1966	NA	NA	651	62	79		
32S/12E-24B03	Screened from 270-435'	1/12/2012	2.15	11.43	660	46	48
		11/21/2011	2.93	10.65	660	43	41
		7/26/2011	3.17	10.41	NA	NA	NA
		7/25/2011	NA	NA	650	46.3	50
		4/20/2011	3.25	10.33	650	47	48
		1/24/2011	2.65	10.58	660	46	44
		10/28/2010	NA	NA	660	44	48
		10/21/2010	4.60	8.63	NA	NA	NA
		7/27/2010	4.54	8.69	610	44	51.4
		4/27/2010	1.43	9.27	666	45	53.2
		1/27/2010	0.94	9.76	672	48	56.4
		10/19/2009	0.81	9.89	622	40	55.1
		8/19/2009	4.18	6.52	680	47	54.9
		5/12/2009	3.18	7.52	645	44	53.2
		3/26/1996	NA	NA	646	41	52
6/9/1976	NA	NA	569	36	53		
1/17/1966	NA	NA	670	79	74		

Table 6b: Northern Cities Sentry Well Water Quality Data Summary

Well	Production Interval	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)
32S/13E-30F01	Screened from 15- 30 and 40-55'						
		1/10/2012	13.80	9.36	460	67	61
		11/21/2011	13.78	9.38	NA	NA	NA
		11/17/2011	NA	NA	470	70	82
		7/26/2011	13.50	9.66	NA	NA	NA
		7/25/2011	NA	NA	460	65.8	68
		4/20/2011	12.82	10.34	460	71	69
		1/24/2011	13.33	9.97	510	75	64
		10/21/2010	16.55	6.75	540	100	73
		7/26/2010	15.68	7.62	464	74	82.2
		4/27/2010	11.02	9.38	534	72	77.1
		1/28/2010	12.73	7.67	725	140	99.9
		10/19/2009	14.33	6.07	522	74	85.6
		8/19/2009	14.34	6.06	648	92	98.9
		5/12/2009	12.38	8.02	792	110	108
32S/13E-30F02	Screened from 75-100'						
		1/12/2012	14.31	8.85	610	52	45
		11/21/2011	14.94	8.22	580	49	38
		7/26/2011	14.46	8.7	NA	NA	NA
		7/25/2011	NA	NA	590	52.1	46
		4/20/2011	14.23	8.93	600	54	57
		1/24/2011	14.36	8.93	600	51	43
		10/28/2010	NA	NA	610	49	38
		10/21/2010	7.39	15.9	NA	NA	NA
		7/26/2010	16.21	7.08	560	49	45.8
		4/27/2010	12.14	8.26	634	51	50.3
		1/28/2010	13.09	7.31	604	44	52.2
		10/19/2009	14.36	6.04	566	49	49.5
		8/19/2009	14.81	5.59	614	49	51.8
		5/12/2009	14.34	2.96	514	54	48.7
		3/27/1996	NA	NA	678	49	52
		6/9/1976	NA	NA	637	48	55
		1/20/1966	NA	NA	580	68	47
32S/13E-30F03	Screened from 305-372'						
		1/12/2012	12.37	10.79	660	46	39
		11/21/2011	13.24	9.92	650	43	33
		7/26/2011	14.22	8.94	NA	NA	NA
		7/25/2011	NA	NA	650	46.5	46
		4/21/2011	NA	NA	650	48	40
		4/20/2011	12.51	10.65	NA	NA	NA
		1/24/2011	12.67	10.64	650	46	36
		10/28/2010	NA	NA	650	46	37
		10/21/2010	6.62	16.69	NA	NA	NA
		7/26/2010	17.32	5.99	608	45	43.8
		4/27/2010	11.38	9.02	668	48	40.8
		1/28/2010	10.98	9.42	656	40	43.1
		10/19/2009	14.18	6.22	626	48	43.3
		8/19/2009	20.23	0.17	672	45	43.1
		5/12/2009	17.68	2.72	678	49	44.8
		3/27/1996	NA	NA	686	41	40
		6/7/1976	NA	NA	616	43	41
		1/19/1966	NA	NA	642	69	49

Table 6b: Northern Cities Sentry Well Water Quality Data Summary

Well	Production Interval	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)
32S/13E-30N01	Screened from 15-40'						
		1/9/2012	8.74	7.39	1,050	260	170
		11/21/2011	8.78	7.35	NA	NA	NA
		11/17/2011	NA	NA	1,300	360	320
		7/26/2011	9.01	7.12	NA	NA	NA
		7/25/2011	NA	NA	1,680	445.3	230
		4/20/2011	8.59	7.54	890	210	130
		1/24/2011	8.18	7.35	870	180	100
		10/21/2010	9.99	5.54	890	190	120
		7/27/2010	8.97	6.56	917	200	130
		4/27/2010	6.14	7.36	808	150	130
		1/26/2010	4.90	8.60	902	210	155
		10/20/2009	6.53	7.00	828	200	159
		8/20/2009	6.71	6.82	835	160	150
		5/11/2009	6.03	7.50	960	180	175
32S/13E-30N03	Screened from 60-135'						
		1/11/2012	7.17	8.96	570	67	55
		11/21/2011	6.45	9.68	600	67	47
		7/26/2011	7.59	8.54	NA	NA	NA
		7/25/2011	NA	NA	590	67	47
		4/20/2011	6.65	9.48	580	76	58
		1/24/2010	6.68	8.75	570	76	48
		10/21/2010	10.76	4.67	550	69	59
		7/27/2010	9.53	5.90	528	72	55.1
		4/27/2010	6.14	7.36	672	89	60.6
		1/26/2010	5.88	7.62	606	110	75.0
		10/20/2009	6.56	6.94	806	180	93.3
		8/20/2009	7.50	6.00	1,070	190	151
		5/12/2009	6.33	7.17	602	97	63.4
		3/27/1996	NA	NA	624	70	62
		6/7/1976	NA	NA	705	90	54
		1/21/1966	NA	NA	804	57	54
32S/13E-30N02	Screened from 175-255'						
		1/11/2012	4.88	11.25	1,040	49	64
		11/21/2011	5.35	10.78	1,020	46	57
		7/26/2011	7.25	8.88	NA	NA	NA
		7/25/2011	NA	NA	1,050	50.4	81
		4/20/2011	3.53	12.60	1,030	52	63
		1/24/2011	3.67	11.76	1,050	50	60
		10/21/2010	10.42	5.01	1,040	48	52
		7/27/2010	10.02	5.41	777	57	67.6
		4/27/2010	5.26	8.27	800	93	71.9
		2/25/2010	1.72	11.78	1,000	48	71.4
		2/25/2010	1.72	11.78	1,010	74	76.9
		1/26/2010	3.72	9.78	970	50	74.2
		10/20/2009	7.38	6.12	2,080	690	274
		8/20/2009	11.94	1.56	1,350	500	199
		5/11/2009	6.98	6.52	1,290	170	129
		3/27/1996	NA	NA	1,050	50	71
		6/7/1976	NA	NA	1,093	48	62
		1/21/1966	NA	NA	1,069	54	71

Table 6b: Northern Cities Sentry Well Water Quality Data Summary

Well	Production Interval	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)
12N/36W-36L01	Screened from 227-237'						
		1/11/2012	17.68	9.09	790	41	64
		11/21/2011	18.08	8.69	910	39	55
		7/26/2011	19.63	7.14	NA	NA	NA
		7/25/2011	NA	NA	890	40.5	65
		4/21/2011	NA	NA	890	42	61
		4/20/2011	18.26	8.51	NA	NA	NA
		1/24/2011	17.61	8.68	890	41	55
		10/21/2010	20.75	5.54	910	38	76
		7/27/2010	21.18	5.11	707	36	64.2
		4/26/2010	15.94	8.06	860	42	70.3
		10/21/2009	17.72	6.28	856	38	72.0
		8/20/2009	19.16	4.84	890	39	78.0
		5/11/2009	17.68	6.32	832	63	83.8
		3/26/1996	NA	NA	882	35	66
		6/8/1976	NA	NA	936	38	72
12N/36W-36L02	Screened from 535-545'						
		1/11/2012	11.18	15.59	900	122	110
		11/21/2011	13.99	12.78	780	130	95
		7/26/2011	18.03	8.74	NA	NA	NA
		7/25/2011	NA	NA	790	128.8	110
		4/21/2011	NA	NA	770	120	90
		4/20/2011	10.33	16.44	NA	NA	NA
		1/24/2011	9.37	16.92	800	120	95
		10/21/2010	19.77	6.52	770	120	130
		7/27/2010	20.53	5.76	737	110	121
		4/26/2010	9.24	14.76	720	100	116
		10/21/2009	17.65	6.35	638	99	113
		8/20/2009	19.15	4.85	785	100	131
		5/11/2009	14.38	9.62	775	120	132
		3/26/1996	NA	NA	772	127	130
		6/8/1976	NA	NA	820	126	118

Table 6b: Northern Cities Sentry Well Water Quality Data Summary

Well	Production Interval	Date	Depth to Water (feet)	Groundwater Elevation (feet NAVD)	Total Dissolved Solids (mg/L)	Chloride (mg/L)	Sodium (mg/L)
Oceano MW-Green	Screened from 110-130'						
		1/12/2012	23.29	11.34	760	76	85
		11/21/2011	22.46	12.17	720	39	38
		7/26/2011	25.51	9.12	NA	NA	NA
		7/25/2011	NA	NA	760	69.3	66
		4/20/2011	114.79	-80.16	NA	NA	NA
		1/24/2011	106.59	-71.96	310	98	22
		10/28/2010	NA	NA	290	81	26
		10/21/2010	112.71	-81.85	NA	NA	NA
		7/26/2010	95.61	-64.75	438	85	34.3
		4/26/2010	63.90	-33.04	560	83	47.7
		1/27/2010	43.71	-12.85	460	130	45.0
		10/20/2009	29.20	1.66	362	92	39.6
		8/19/2009	24.55	6.31	420	160	48.4
		5/16/1983	15.80	15.06	665	35	40
Oceano MW-Blue	Screened from 190-210' and 245-265'						
		1/12/2012	22.26	12.37	480	96	110
		11/21/2011	22.73	11.90	390	90	78
		7/26/2011	25.29	9.34	NA	NA	NA
		7/25/2011	NA	NA	260	29.3	23
		4/21/2011	NA	NA	580	118	70
		4/20/2011	22.59	12.04	NA	NA	NA
		1/24/2011	24.87	9.76	680	110	60
		10/21/2010	30.11	0.80	770	100	68
		7/26/2010	24.74	6.17	783	130	80.1
		4/26/2010	18.52	12.39	1,130	160	70.2
		1/27/2010	22.06	8.85	1,740	430	55.6
		10/20/2009	27.50	3.41	2,250	1,000	19.5
		8/19/2009	24.65	6.26	322	150	93.2
		5/16/1983	13.30	17.61	840	80	90
Oceano MW-Silver	Screened from 395-435' and 470-510'						
		11/21/2011	23.00	11.63	NA	NA	NA
		7/26/2011	25.23	9.4	NA	NA	NA
		4/21/2011	NA	NA	410	97	100
		4/20/2011	21.27	13.36	NA	NA	NA
		1/24/2011	22.02	12.61	440	92	90
		10/21/2010	29.11	1.74	460	90	110
		7/26/2010	24.24	6.61	478	83	109
		4/26/2010	19.04	11.81	452	83	83
		1/27/2010	21.05	9.8	496	71	92.2
		10/20/2009	27.52	3.33	564	71	80.8
		8/19/2009	29.34	1.51	522	180	148
		5/16/1983	13.50	17.35	630	40	40
Oceano MW-Yellow	Screened from 625-645'						
		1/12/2012	23.08	11.55	410	94	95
		11/21/2011	22.98	11.65	410	94	83
		7/26/2011	26.73	7.90	NA	NA	NA
		7/25/2011	NA	NA	420	89.7	84
		4/21/2011	NA	NA	380	88	110
		4/20/2011	21.30	13.33	NA	NA	NA
		1/24/2011	22.01	12.62	430	83	73
		10/21/2010	28.22	2.67	410	87	100
		7/26/2010	25.50	5.39	446	94	93.0
		4/26/2010	19.17	11.72	416	96	87.6
		1/27/2010	20.58	10.31	498	89	79.6
		10/20/2009	25.80	5.09	446	100	97.1
		8/19/2009	31.04	-0.15	426	160	101
		5/16/1983	14.30	16.59	770	60	70

Sentry well cluster 32S/13E 30N is located west of Highway 1 in Oceano and includes three piezometers. The sentry well cluster is also in an area of sufficient groundwater production to cause a broad lowering of the water table (called a pumping trough by Todd Engineers 2010). The deep and intermediate level piezometers at this location showed low groundwater levels in 2008 and 2009. Data from this sentry well cluster was interpreted to indicate localized seawater intrusion affecting the deep zone (30N02) and, to a lesser extent, the middle zone (30N03) in 2009.

Data collected in 2010 from piezometers 30N02 and 30N03 show geochemical signatures of seawater intrusion on Schoeller geochemical plots (Figure 15). (A Schoeller diagram is a graphical representation of common cation and anion concentrations in water expressed in milliequivalents per liter (meq/l). Because several samples may be plotted on the same graph, variation in hydrogeochemical water characteristics may be easily recognized.) The most recent water quality data from this well cluster (January, April, July and October 2011) show significant improvement in water quality in 30N02, including a reduction in the concentrations of seawater indicators and a signature similar to the historical signature of groundwater in 30N02.

These water quality changes indicate that the local interface/mixing zone between seawater and fresh groundwater has shifted in the seaward direction. The location of the seawater interface is not known due to the heterogeneity of the aquifer; the only indication is when one or more monitored wells show an increase in TDS and a geochemical signature resembling seawater. Based on experience in the NCMA, retreat of the interface may be reversed, and again become shoreward, if seaward gradients are reduced or reversed. These changes may be brought on by reduced recharge (e.g. drought conditions) or if pumping exceeds available groundwater supply, or both. Ongoing sentry well monitoring is necessary to provide an early warning of future migration of the interface.

The shallow well in sentry well cluster 32S/12E 24B has historically contained brackish water. This sentry well is located in the northwestern corner of the basin in Pismo Beach. The shallow well (24B01) shows a similar geochemical signature to that of seawater. Water samples from this well historically have shown high sodium and chloride concentrations. While these data have been interpreted by the California Department of Water Resources to be the result of solution of residual marine and evaporative salts indigenous to the geologic environment in this part of the basin, there may be another source. The location of 32S/12E 24B is near the lagoon at the mouth of Pismo Creek. This area is subject to storm surge and local flooding during storm and high sea conditions. The water sample from the shallow piezometer (24B01) showed elevated Cl and Na in October 2010 and all quarterly samples taken in 2011 while samples from the two deeper piezometers showed no such effect. Occasional downward percolation of seawater or brackish lagoon water may influence the quality of sample from the shallow piezometer (24B01). A sensor has been installed to measure short term fluctuations in water level and TDS to provide additional insight as to the

source of Cl and Na fluctuations. However, no correlation has been established between exceptionally high tides or storm surges and increases in electrical conductivity.

Schoeller diagrams are geochemical representations that show the relative portions of major water quality constituents based on ionic charge (in milliequivalents per liter or meq/L). This approach allows graphical, or visual, means to evaluate measured water quality against potential water sources. Figure 15 is a Schoeller diagram illustrating the water quality in the DWR sentry wells for all of the 2011 quarterly monitoring events. Each line of connected points illustrates the water quality signature from a specific well (e.g., 30N02) for a given sample period. For comparison, Figure 15 (the Schoeller diagram) also shows the typical geochemical signature for seawater (in black) and the typical signature for a groundwater basin water supply well (Grover Beach Well#1, labeled as “GW Base”, in blue). Most of the water quality samples plotted on the lower portion of the diagram are similar in shape to the groundwater basin sample and are combined within the shaded area.

The Oceano CSD Observation well cluster has four wells; from shallow to deep, they are identified as green, blue, silver, and yellow (see Figures 7 and 8). As documented in Table 6A, the Oceano CSD observation wells have been sampled in each quarterly monitoring event since August 2009, but have not shown consistent water quality chemistry. In general, the two deeper Oceano CSD Observation wells show similar water quality to the rest of the groundwater basin with the exception of low sulfate values reported in August 2008. Chloride concentrations have been slightly elevated and peaked in August 2009; however, the overall water quality character does not appear to indicate seawater intrusion.

In the past few years the two shallow Oceano CSD Observation wells have shown significant variation in several water quality parameters. In addition the wells recovered slowly after purging done as part of sampling. This suggested some disconnect from the screened zone and may indicate scaling or other chemical process is occurring. In order to restore function of the Oceano CSD wells, high pressure flushing “jetting” of the screened interval in each well was attempted.

Jetting to clear obstructions in the Oceano CSD “Green” and “Blue” wells were successful and water levels were found to recover quickly after purging during sampling. Rehabilitation of Oceano CSD Silver well found the casing blocked above the screened interval suggesting a portion of the casing had failed. The screened interval in the Yellow well was not jetted since the available equipment was not able to reach to the screened depth of 625 ft. Because the Silver well appears to be damaged, water level measurements and water quality samples were obtained from Oceano CSD production well #8 which has a similar screened interval.

As documented in Table 6A, chloride concentrations from the blue well were elevated in October 2009 but have fallen since January 2010 and are now in a range similar to other sentry wells. However, the water quality from this well suggests a signature close to groundwater not seawater.

Public water supply systems are required to provide water quality information to the DPH. Data submitted from the NCMA area was reviewed and most recent data added to the NCMA data base. Although the data supplied by DPH does not include specific well locations, individual public supply wells are identified and their location determined.

Although there is variation among wells, data from 2011 suggest that water quality in individual wells has remained generally consistent from year to year. High levels of Nitrate, Selenium and Manganese are present in some wells. These wells are subject to more frequent sampling and water produced is subject to treatment or blending. Treatment to remove selenium and manganese and blending result in the water delivered through the municipal systems meeting State and Federal water quality standards.

4.3 Threats to Water Supply

Both state-wide and local impacts to the NCMA water supply exist. Because the water supply contains sources imported from other areas of the state, threats include State-wide drought, effects of climate change in the SWP source area, management and environmental protection issues in the Sacramento-San Joaquin Delta that affect the amount and reliability of SWP deliveries and seismic risk to the SWP delivery system. Local potential impacts to NCMA water supply similarly include extended drought and climate change that may affect the yield from Lopez Lake as well as reduced recharge to the NCMA. There is a potential impact from seawater intrusion if the groundwater system is not adequately monitored (as discussed in the above section).

4.3.1 Threats to State Water Project Supply

Both extended drought and long term reduction in snowpack due to climate change can affect deliveries from the State Water Project. California experienced a relatively short (2 year) drought that resulted in below-average precipitation and runoff in the SWP source area; runoff in 2007 and 2008 amounted to only 53 and 60 percent of average, respectively, and runoff in 2009 was only slightly better at 85 percent. As a result, storage in SWP reservoirs was reduced. In addition to drought conditions, SWP pumping capacity was reduced as the result of a May 2007 federal court ruling to protect Delta smelt.

However, the threat of reduced delivery to local SWP users—Oceano CSD and Pismo Beach—has not materialized to date, as San Luis Obispo County’s allocation continues to be approved in full because the FC&WCD is able to use some of its unallocated Table A amount to augment deliveries. The FC&WCD hold SWP allocation in addition to the amount needed to meet contracts with local agencies. In addition, the City of Pismo Beach

acquired additional allocation from FC&WCD in 2012. Both sources of extra allocation may be used as a drought buffer to provide additional deliveries during years when full deliveries are not available. Nonetheless, in the future, the Delta's fragile ecosystem, uncertain precipitation patterns and reduced snowmelt may further reduce California's water supply reliability with potential ramifications for Oceano CSD and Pismo Beach.

4.3.2 Seawater Intrusion

The NCMA is underlain by an accumulation of alluvial materials that slope gently offshore and extend for many miles under the ocean (DWR 1985). Coarser materials within the alluvial materials comprise aquifer zones that receive freshwater recharge in areas above sea level. The elevation difference causes fresh water in the aquifers to flow toward the ocean and form an interface between freshwater and seawater. Under natural and historical conditions the differential pressure between the aquifer and seawater induces net outflow of freshwater and establishes a dynamic interface between fresh water and salt water at depth. Sufficient outflow prevents the dynamic interface from moving onshore. Sufficient differential pressure to maintain a net outflow is indicated by onshore groundwater elevations that are above mean sea level.

The Annual Report for CY 2008 documented that a portion of the NCMA groundwater basin exhibited water surface elevations below sea level (Todd Engineers 2009). Hydrographs for NCMA sentry wells (Figures 10 and 11) show coastal groundwater elevations that were at relatively low levels for as long as two years. Such sustained low levels had not occurred previously in the historical record and reflected the impact of drought on groundwater levels. The low coastal groundwater levels indicated a potential for seawater intrusion. Increased TDS, Na and Cl concentrations were found in sentry well 32S/13E N03 in August 2009 and in 32S/13E N02 in August and October 2009.

As documented in Section 4.2.2 of this report, groundwater elevations in October 2011 showed a significant recovery of groundwater elevations relative to October 2008 and October 2009. In addition, groundwater quality in the sentry wells N02 and N03 showed improvement beginning in January 2010, including a reduction in the concentrations of seawater indicators. Water elevation and quality measurements in 2009 through October 2011 indicate the following:

- The monitoring of the sentry wells, notably 32S/13E 30N, provides an early warning of seawater intrusion. This well cluster may be relatively sensitive to seawater intrusion because of its location near Arroyo Grande Creek and the more permeable sediments deposited by the ancestral creek (Todd Engineers 2010).
- The initial portions of the seawater/groundwater interface were detected onshore at one site beginning with elevated Chloride levels in May 2009; by October 2009 the interface had manifested in the middle and deep aquifer zones monitored by sentry wells 30-N02 and 30-N03. The extent to which seawater may have intruded other localized aquifer zones along the coast without being detected in the NCMA sentry

wells is unknown due to heterogeneity of the aquifer and spacing of sentry wells. This uncertainty may be reduced by the ongoing collection of coastal groundwater elevations in all sentry wells which are above mean sea level.

- Above average precipitation and decreased groundwater withdrawal in 2010 resulted in increased water levels in the sentry wells on a comparative seasonal basis and an apparent decrease in water table depression immediately south of lower Arroyo Grande Creek. Average rainfall and groundwater withdrawals in 2011 have maintained this condition. (Figures 9A and 9B).
- Water quality in most wells remains similar to historic measurements thus indicating no effects of seawater intrusion.

4.3.3 Measures to Avoid Seawater Intrusion

In response to the early warning of seawater intrusion, the Northern Cities have developed and implemented a water quality monitoring program for the sentry wells and Oceano CSD Observation wells, as described above in Section 4.2.3. The Northern Cities, County FC&WCD, and State of California have also worked cooperatively toward the protection of the sentry wells as long-term monitoring sites. To address the impacts of potential seawater intrusion, the Northern Cities have voluntarily reduced coastal groundwater pumping, decreased overall water use via conservation, and initiated plans, studies and institutional arrangements to secure additional surface water supplies. As a result, each of the 4 major municipal water users reduced groundwater use between 25 and 90 percent between 2007 and 2010. In 2011, groundwater use ranged between 7 and 67 percent compared to 2007. Pismo Beach and Oceano CSD reduced their groundwater demand between 90 and 50 percent respectively, in part by importing SWP supplies. A summary of the Northern Cities Management Area objectives and activities is presented below in Section 6.

4.3.4 Change in Groundwater Recharge

Groundwater recharge includes subsurface flow from adjacent areas into aquifers serving as water sources in the NCMA. An important source of subsurface recharge is flow from the NMMA along the southeast boundary of the NCMA, estimated to be 1,300 AFY (DWR 2002). Contour maps prepared by DWR for spring 1975, 1985, 1995 and 2000 indicate a growing depression in the NMMA associated with increased pumping during the same time period (DWR 2002).

More recently the NMMA Annual Report for 2009, (Figures 6-5 and 6-6) confirm persistence of a NW/SE trending depression in the water level contours. Despite above average rainfall in 2010, this zone of lower water levels appears to have persisted through fall 2010 based on Figure 6-6 of the NMMA 2010 Annual Report and into fall 2011, as shown in Figure 9B of this report.

The NMMA 2010 Annual Report projects increasing water demand, thus extraction from groundwater, in the NMMA. Although the NMMA may receive supplemental sources in the future, ongoing or increasing amounts of groundwater extraction may continue to lower ground water levels along the NMMA and NCMA boundary. Lower groundwater levels in the boundary area will reduce flow to the NCMA or even reverse the flow; either circumstance would further reduce groundwater available to users in the NCMA.

Some NCMA representatives have expressed their concerns to NMMA representatives regarding the threats to the groundwater supply of both management areas, threats caused by the increasing overdraft in the NMMA. The NCMA continues to work together with the NMMA to better understand and solve these problems.

5 Supply/Demand Comparison

This section presents a comparison of the 2011 water supplies and demands of the Northern Cities Management Area, applied irrigation, and rural water systems.

Table 5 in Section 4 outlines the Available Urban Water Supplies for each of the Northern Cities. The total available urban water supply is 10,769 AFY. As discussed in Section 4, the 2002 Settlement Agreement estimated that the historical safe yield from the groundwater basin was 9,500 AFY. Since all of the irrigation applied water demand is supplied by groundwater, the total available applied irrigation supply is based on a portion of the estimated groundwater safe yield, which was allocated as 5,300 AFY for agricultural and rural use. The agricultural conversion of 330 AFY reduces this allocation to 4,970 AFY. Of this estimated safe yield of 9,500 AFY, other than what is allocated for applied irrigation and rural use, the remaining 4,000 AFY is allocated for urban water use and 200 AFY allocated to subsurface outflow to the ocean.

In 2011, the total urban water demand, based on production, was 7,473 AF. Based on 2011 precipitation and ET data, 2011 applied irrigation water use was estimated at 2,742 AF, while rural water use was estimated at 38 AF. The total combined demand for the NCMA in 2011 was 10,253 AF. The following Table 7 displays the water demand, by source, of each city and agency in 2011.

Table 7 2011 Water Demand by Source (AF)

Urban Area	Lopez Lake	State Water Project	Groundwater	Transfers	Other Supplies	Total
Arroyo Grande	2,572.37	0	211.40	0	137.90	2,921.7
Grover Beach	921.08	0	866.13	0	0	1,787.2
Pismo Beach	1,055.88	809.40	47.11	0	0	1,912.4
Oceano CSD	57.46	750.00	44.28	0	0	851.7
Urban Water Use Total	4,606.79	1,559.40	1,168.92	0	137.90	7,473
Applied Irrigation	0	0	2,742	0	0	2,742
Rural Water Users	0	0	38	0	0	38
Total	4,607	1,559	3,949	0	138	10,253

Urban water demand in 2011 to the NCMA totaled 4,607 AF of Lopez Lake water, 1,559 AF of State Water Project water, and 1,169 AF of groundwater. Neither Arroyo Grande, nor Grover Beach, has a State Water Project allocation. Arroyo Grande has a temporary agreement to purchase 100 AFY of water from Oceano CSD for the next two years. The agreement is in its 4th year and is set to expire after 2013. The 138 AF of “Other Supplies”

delivered to Arroyo Grande consists of groundwater pumped from the Pismo Formation, which is located outside of the shared groundwater basin.

Based on the estimated groundwater safe yield, the total available supply for all uses is 15,748 AFY, which is the sum of 10,769 AFY for urban plus the allocation for applied irrigation and rural area of 4,979 AFY. Total applied water demand by source was estimated at 10,253 AFY for 2011.

6 Management Activities

Section 6 is divided into two parts: the first section presents the primary NCMA groundwater management objectives and summarizes major historical management activities relevant to the objectives. The second section describes management activities in 2011.

The group of NCMA groundwater users involved in the stipulation, the Northern Parties, comprises the Northern Cities, the overlying owners, San Luis Obispo County and San Luis Obispo County FC&WCD have actively managed surface water and groundwater resources for more than 30 years. Management objectives and responsibilities were first established the 1983 *Gentlemen's Agreement* and updated in the 2002 Settlement Agreement. The responsibility and authority of the Northern Parties for NCMA groundwater management was formally established through the 2002 Settlement Agreement, 2005 Stipulation, and 2008 Judgment. The overall management goal for the Northern Cities is to preserve the long-term integrity of water supplies in the NCMA portion of the Santa Maria Groundwater Basin (SMGB).

6.1 Management Objectives

Seven basic objectives have been established for ongoing NCMA groundwater management. Under each objective, the NCMA technical group has identified a number of strategies to meet the objectives. These strategies are shown under each of the seven objectives listed below:

1. Share Groundwater Resources and Manage Pumping

- Continued reduction of groundwater pumping, maintain below safe yield.
- Coordinated delivery of Lopez Lake surplus water to maximize surface water supplies.
 - Transfer of Lopez Lake surplus water between Oceano CSD and Arroyo Grande.
 - Temporary purchase of 100 AFY of water by Arroyo Grande from Oceano CSD, which expires after 2013.
- Continue to import State Water Project supplies to Oceano CSD and Pismo Beach.
- Performed capacity assessments on the Lopez Lake and Coastal Branch pipelines to allow maximum current and future surface water imports.
- Performed pigging on the Lopez Lake pipeline to increase delivery capacity.

- Maintain surface water delivery infrastructure to maximize capacity.
 - 18” Lopez Lake Pipeline Pigging Project
 - 33” Lopez Lake Pipeline Pigging Project

2. Monitor Supply and Demand and Share Information

- Share monthly groundwater pumping data at NCMA TG meetings.
- Evaluate future water demands through comparison to UWMP projections.
 - Arroyo Grande 2010 UWMP
 - Pismo Beach 2010 UWMP
 - Grover Beach 2010 UWMP

3. Manage Groundwater Levels and Prevent Seawater Intrusion

- Utilize of storm-water ponds to capture storm-water run-off and recharge the groundwater basin.
- Install transducers in key monitoring wells to provide continuous groundwater elevation data; the following wells have transducers:
 - 24B01
 - 24B03
 - 30F03
 - 30N02
 - County Monitoring Well #3
- Collect and evaluate daily municipal pumping data to determine impact on local groundwater elevation levels.
- Coordinate with FC&WCD to install a transducer in the new County Monitoring Well #3 on the NCMA/NMMA boundary.
- Coordinate pursuit of IRWM Planning and LGA grant funding to characterize the SMGB and develop a groundwater flow model.

4. Protect Groundwater Quality

- Perform additional water quality monitoring at new County Well #.3
- Install temperature and electrical conductivity probes in 5 monitoring wells to continuously track water quality indicators for seawater intrusion.
- Characterize groundwater basin in preparation for the development of a Salt and Nutrient Management Plan.
- Investigate using recycled water in a seawater intrusion barrier.

5. Manage Cooperatively

- Include the Santa Maria Valley Management Area (SMVMA) in the Santa Maria Groundwater Basin Management Areas (SMGB MA) Technical Subcommittee.
- Coordinate groundwater monitoring data sharing and annual report preparation with the NCMA, NMMA and the SMVMA.

6. Encourage Water Conservation

- Share updated water conservation information
- Implement UWMPs

7. Evaluate alternative sources of new developed water (Stipulation Section IV)

- Addressed through importation of additional SWP supplies and expanded use of recycled water
- Analyze capacity of the Lopez Lake and Coastal Branch pipelines to maximize deliveries of surface water. For example:
 - Lopez Lake Pipeline Capacity Evaluation
 - Lopez Lake Pipeline Capacity Re-Evaluation
 - Coastal Branch Capacity Assessment

The history and rationale are discussed in the sections below. Other potential objectives are outlined in the final section.

6.1.1 Share Groundwater Resources and Manage Pumping.

A longstanding objective of water users in the NCMA has been to cooperatively share and manage groundwater resources. In 1983 the Northern Parties mutually agreed on an initial safe yield estimate (defined by DWR) and an allotment of pumping between the urban users and applied irrigation users of 57 percent and 43 percent respectively. In this agreement the Northern Cities also established pumping allotments among themselves. Subsequently the 2002 Settlement Agreement included provisions to account for changes such as land conversion. The agreements provide that any increase or decrease in the safe yield based on ongoing assessments would be shared on a pro rata basis. Pursuant to the stipulation the Northern Cities conducted a water balance study to update the safe yield estimate (Todd Engineers 2007). Among other results, the parties agreed to maintain the existing pumping allotment among the urban users and established a consistent methodology to address agricultural land use conversion.

In addition to cooperatively sharing and managing groundwater resources, the Northern Cities have coordinated delivery of water from Lopez Lake, and have continued to import SWP water to maximize use of available surface water supplies. A total of 100 AFY of Lopez Lake entitlement, or groundwater allotment, is made available for Arroyo Grande to

purchase from Oceano CSD via a temporary purchase agreement. Oceano CSD and Pismo Beach continue to import SWP water. These activities have allowed the Northern Cities, as a whole, to reduce the amount of groundwater that is pumped from the shared basin.

Along with coordination activities to maximize surface water supplies, the Northern Cities have performed capacity assessments on the Lopez Lake and Coastal Branch pipelines to maximize current and future surface water imports. A portion of the Lopez Lake pipeline has been “pigged” (a cleaning and maintenance procedure) to increase delivery capacity as well.

The water balance study also highlighted the threat of seawater intrusion as the most important potential adverse impact to consider in managing the basin. Seawater intrusion, a concern since the 1960s, would degrade the quality of water in aquifer and potentially render portions of the basin unsuitable for groundwater production (DWR 1970).

Another potential adverse impact of localized pumping includes reduction of flow in local streams, notably Arroyo Grande (Todd Engineers 2007). The Northern Cities (as Zone 3 contractors) have participated with FC&WCD in preparation of the Arroyo Grande Creek Habitat Conservation Plan (HCP) that addresses reservoir releases to maintain both groundwater levels and habitat diversity in the creek.

6.1.2 Monitor Supply and Demand and Share Information

Regular monitoring of activities that affect the groundwater basin, and sharing that information, has occurred for many years. Monitoring includes gathering data on hydrologic conditions, water supply and demand, and groundwater pumping, levels, and quality. This was first established in 1983 and then formalized in 2002 to include quarterly meetings. The current monitoring program is managed by the Northern Cities in accordance with the 2005 Stipulation and 2008 Judgment, guided by the July 2008 Monitoring Program for the NCMA. The data and its implication to groundwater management are summarized in the Annual Reports. Arroyo Grande, Grover Beach, and Pismo Beach have each evaluated their future water demands as part of their respective 2010 UWMP updates. The NCMA has engaged the two other management areas and now shares information through data exchange and regular meetings throughout the annual report preparation cycle.

6.1.3 Manage Groundwater Levels and Prevent Seawater Intrusion

Prevention of seawater intrusion through the management of groundwater levels is essential to protecting the shared resource. While closely related to the objectives to manage pumping, monitor supply and demand, and share information, this objective specifically recognizes the proximity of production wells to the coast and the threat of seawater intrusion. The Northern Cities, County and FC&WCD have long cooperated in the monitoring of groundwater levels, including quarterly measurement of groundwater levels in the sentry wells at the coast. Upon assuming responsibility for the coastal monitoring wells, the NCMA became aware of the need to upgrade their condition. In July 2010 the well-heads

(surface completions) at four sentry monitoring well clusters within the Northern Cities Management Area were renovated (Todd Engineers 2010). The modifications occurred at well clusters:

- 32S/12E-24B01, B02, B03
- 32S/13E-30F01, F02, F03;
- 32S/13E-30N01, N02, N03
- 12N/36W-36L01, L02

The renovations included raising the elevations of the top of each individual well casing by two to three feet in order to reduce the risk of surface water entering the wells. Because the top of the well casing is used as the reference point for all depth to water measurements, the new surface completions were surveyed relative to the NAVD 88 standard in late September 2010 (Wallace Group 2010). (Changes in the wellhead elevations are indicated in Tables 6A and 6B.) The individual well casings have been raised above ground surface and protective locking steel risers now enclose each cluster. As a result of this work, the sentry wells within the NCMA are now protected from surface contamination and tampering.

While quarterly measurement of groundwater levels aids in assessing the risk of seawater intrusion along the coast, the NCMA has installed transducers in 5 monitoring wells to provide continuous groundwater levels at key locations. By combining this with the collection and evaluation of daily municipal pumping data, the NCMA hopes to be able to determine the response of local groundwater levels to extractions and therefore better manage the basin.

As a result of lowering of water levels during 2007 and 2008, the Northern Cities reduced pumping from the basin and requested increased SWP deliveries. This response has allowed groundwater levels to rise to a level apparently sufficient to prevent seawater intrusion (see Section 4.2 of this report).

6.1.4 Protect Groundwater Quality

The objective to protect groundwater quality is closely linked with the objective for monitoring and data sharing. To meet this objective all sources of water quality degradation, including the threat of seawater intrusion, need to be recognized. Water quality problems could affect the integrity of groundwater supplies, resulting in loss of use or expensive water treatment processes. Sentry wells are monitored quarterly and data from other NCMA production wells are assessed annually. The monitoring program includes evaluation of potential contaminants in addition to those that might indicate seawater intrusion. Temperature and electrical conductivity probes have been installed in 5 monitoring wells to provide continuous water quality tracking for early indication of seawater intrusion. For example, local nitrate and selenium concentrations in excess of primary drinking water standards have been addressed through actions such as provision of municipal water to

private domestic users and through nitrate removal or blending to ensure that delivered water meets all drinking water standards. Additionally, the groundwater basin is being characterized in preparation for the possible development of a Salt and Nutrient Management Plan.

6.1.5 Encourage Water Conservation

Water conservation, or water use efficiency, is linked to the monitoring of supply and demand and the management of pumping. Water conservation would reduce overall demand on all sources, including groundwater, and support management objectives to manage groundwater levels and prevent seawater intrusion. In addition water conservation is consistent with State policies seeking to achieve significant water use reductions by the year 2020. Water conservation activities in the NCMA are summarized in various documents produced by the Northern Cities, including the 2010 Urban Water Management Plans of Arroyo Grande, Grover Beach, and Pismo Beach.

6.1.6 Manage Cooperatively

Since 1983, NCMA management has been based on cooperative efforts of the affected parties themselves including the four Northern Cities with ongoing collaboration with San Luis Obispo County, the FC&WCD, and other local and state agencies. Other organizations participate as appropriate to the issues of the time. In addition to the efforts discussed in the report, cooperative management occurs through many means including communication by the Northern Cities in their respective public meetings and participation in the Water Resources Advisory Council (the County-wide advisory panel on water issues).

The NCMA agencies participated in preparation and adoption of the 2007 San Luis Obispo County Integrated Regional Water Management Plan (IRWMP). The IRWMP promotes integrated regional water management to ensure sustainable water uses, reliable water supplies, better water quality, environmental stewardship, efficient urban development, protection of agriculture, and a strong economy. The IRWMP integrates all of the programs, plans, and projects lead by entities within the region into water supply, water quality, ecosystem preservation and restoration, groundwater monitoring and management, and flood management programs. The IRWM Plan is in the process of being revised and NCMA agencies are participating.

6.1.7 Other Potential Management Objectives

Based on information developed in preparation of this Annual Report and other management activities (discussed in Section 6.2), it may be appropriate to develop other management objectives to address:

- Optimizing sources to best provide for prolonged droughts (Todd Engineers 2007)
- Optimizing location and rate of groundwater pumping to protect groundwater quality (Todd Engineers 2007)

- Calculating target gradient to prevent seawater intrusion (Miller and Evenson 1966)
- Assessing basin response to recharge and use based on drought cycle

6.2 Update on Management Activities

The Northern Cities, both individually and jointly, are engaged in water resource management projects, programs, and planning efforts that address water supply and demand issues, particularly efforts to assure a long-term sustainable supply. This section discusses major management activities during 2011. These management activities, taken as a whole, address all of the Management Objectives described in Section 5.

6.2.1 Expansion of Groundwater Monitoring

Groundwater monitoring has been expanded in order to address objectives relating to managing groundwater levels and preventing seawater intrusion, protecting groundwater quality, and managing pumping. In 2009 the sentry well monitoring program was intensified to include quarterly water quality sampling and analysis. A project to renovate the sentry wells also was initiated. In July 2011 the tops each piezometer casing in the sentry well locations were raised above land surface to avoid the potential of surface runoff entering the casing. In addition the protective well casing was modified to prevent tampering. Each modified well was resurveyed relative to the North American Vertical Datum (NAVD) 88. In 2011 continuous monitoring equipment was installed in three deep sentry wells and one shallow well to gather data on short term water level fluctuations potentially caused by tidal influences and groundwater extractions. Continuous monitoring equipment will be installed in a newly constructed well in 2012 to measure water level and electrical conductance changes on the southern edge of the NCMA.

6.2.2 Control of Groundwater Levels and Seawater Intrusion

The Northern Cities that may accept SWP deliveries have requested a one-time augmentation of their allocation. Continuing importation of State Water project supplies will allow the users in NCMA to reduce groundwater demand. This allows the County to store up to 1500 AF of emergency water to reduce coastal seawater intrusion, and also allows the County to store water in Lopez Lake for future emergency use. In addition, each of the Northern Cities was able to reduce its groundwater use below its safe yield allotment in 2011.

6.2.3 Cooperative Water Supply Planning and Management

Water supply planning and management activities in 2011 included an ongoing water supply agreement between Arroyo Grande and Oceano CSD, ongoing recharge using storm water detention ponds, sentry well monitoring, data sharing, regional agreements, implementation of additional water conservation measures, and ongoing studies to acquire new water supply sources. Pursuant to State law, three of the NCMA members prepared Urban Water Management Plans that document current supply and demand as well as project future supply

and demand. In addition, Oceano CSD is in the process of completing its Water and Sewer Master Plan that details their water system and provides water shortage contingency plans.

Water Transfer

In January 2009, Arroyo Grande entered into temporary agreement with Oceano CSD to purchase an additional 100 AFY of supplemental water supply. This agreement will expire after 2013.

Storm Water Ponds

Arroyo Grande, Grover Beach, and Oceano CSD each maintain storm water retention ponds. These ponds collect storm water runoff, allowing it to recharge the underlying aquifers. There are approximately 140 acres and 48 acres of detention ponds in Arroyo Grande and Grover Beach, respectively. The existing storm water detention pond in Oceano CSD is approximately half an acre. Grover Beach recently modified its storm water system to direct additional flow into one of its recharge basins. San Luis Obispo County is currently evaluating creation of a 50-acre storm water detention pond near the Oceano Airport. This pond would also create an opportunity for recharge to the groundwater basin. The *Oceano Drainage and Flood Control Study* documents the need for such a pond and identifies the steps required to implement the facility.

Data Sharing

The Northern Cities cooperate with San Luis Obispo County and the Nipomo Mesa Management Area (NMMA) in the improvement of regional groundwater monitoring. Consistent with state Law, 3 NCMA cities have adopted updated UWMPs to include 2010 data, projections of supply and demand as well as estimates of daily per capita demand. During preparation of each Annual Report, the Northern Cities and NMMA also share water quality data and collaborate on the interpretation of groundwater level data and preparation of water elevation contour maps.

6.2.4 Water Conservation

The Northern Cities implement water conservation activities to reduce water use and thus reduce groundwater demand. The Cities participate in a wide range of water conservation activities designed to educate the public on ways to reduce water use.

City of Arroyo Grande

The City of Arroyo Grande supports a part time water conservation coordinator staff position to manage existing conservation activities, encourage public participation, and create new conservation programs for the community. In the last eight years, Arroyo Grande spent over \$1,000,000 on water conservation efforts. Arroyo Grande is implementing the following water Demand Management Measures (DMMs):

- Water Survey Programs (Equivalent program elements)
- Residential Plumbing Retrofits

- Water System Audits
- Metering with Commodity Rates
- Large Landscape Irrigation Programs
- High-efficiency washing machine rebate programs
- Public information programs.
- School education programs.
- Conservation programs for commercial, industrial, and institutional accounts.
- Conservation pricing.
- Water conservation coordinator.
- Water waste prohibition.
- Residential ultra-low-flush toilet replacement programs.
- Cash for Grass

The water conservation efforts of Arroyo Grande have been very successful to date; the DMMs that have been implemented have decreased water use per residential connection from 190 gpcd to 156 gpcd. The target per capita usage for 2015 is 167 gpcd, while the target per capita usage for 2020 is 149 gpcd. Continued implementation of these BMPs will help Arroyo Grande to reach its per capita water use goals and indicates the commitment Arroyo Grande has to optimizing use of its water supply. Arroyo Grande is developing a program to evaluate the effectiveness of the water conservation program pursuant to Water Code Section 10631 (g).

City of Pismo Beach

The City of Pismo Beach is a member of the California Urban Water Conservation Council, and as such has developed best management practices (BMPs) to reduce water consumption and ensure reliable future water supply. Included in BMPs implemented by Pismo Beach are activities and programs that promote water conservation and sustainable use of water resources. BMPs that Pismo Beach is implementing or has equivalent coverage are:

- Water Survey Programs
- Residential Plumbing Retrofit
- Water System Audits
- Metering with Commodity Rates
- Landscape Irrigation Programs
- Conservation Pricing
- Water Conservation Coordinator

- Ultra Low Flush Toilet Replacement

The water conservation efforts of Pismo Beach have helped reduce residential water use from a high of 256 gpcd in 2007, to 226 gpcd in 2010. The 10-year baseline average water use is 236 gpcd. Continued implementation of these BMPs and implementation of other BMPs in the future will help Pismo Beach reach its per capita water use goals and indicates the commitment of Pismo Beach to optimizing use of its water supply. The target water use for 2015 is 214 gpcd, while the target water use for 2020 is 192 gpcd.

City of Grover Beach

As described in their 2010 Urban Water Plan, Grover Beach has developed and implemented Demand Management Measures to reduce water consumption and ensure reliable future water supply. Included in the DMMs implemented by the Grover Beach are activities and programs that promote water conservation and sustainable use of water resources. DMMs that Grover Beach is implementing or has equivalent coverage are:

- Water survey programs for single-family residential and multifamily residential customers
- Residential plumbing retrofit
- System water audits, leak detection, and repair
- Metering with commodity rates for all new connections and retrofit of existing connections
- Large landscape conservation programs and incentives
- High-efficiency washing machine rebate programs
- Public information programs
- School education programs
- Conservation programs for commercial, industrial, and institutional accounts
- Conservation pricing
- Water conservation coordinator
- Water waste prohibition
- Residential ultra-low-flush toilet replacement programs

Grover Beach has implemented or is planning to implement all applicable demand management measures as part of the Water Conservation Program. The ongoing water conservation activities of Grover Beach include a “Cash for Grass” rebate, a water-efficient washing machine rebate program, and smart irrigation controller and sensor rebate program. The 10-year baseline average water use for Grover Beach is 140.7 gpcd. The target water use for 2015 is 127 gpcd, while the target water use for 2020 is 113 gpcd.

6.2.5 Alternative Water Supply Studies

The Northern Cities continue to evaluate alternative sources of water supply which could provide a more reliable and sustainable water supply for the NCMA. An expanded portfolio of water supply sources will support sustainable management of the groundwater resource and help to reduce the risk of water shortages. These alternative sources include:

State Water Project

As discussed above, the Northern Cities have requested a short-term allocation of 1,500 AF for the NCMA. Oceano CSD and Pismo Beach are currently SWP customers and could use additional water immediately. Grover Beach is not a SWP customer; however, Grover Beach could indirectly benefit from the water assuming that the allocation is granted. If successful, a longer term allocation could be evaluated based on the existing FC&WCD allotment from the SWP.

Water Recycling

In 2010, the South San Luis Obispo County Sanitation District (SSLOCS D) updated their 2001 evaluation of recycled water opportunities. The new evaluation included an evaluation of using disinfected secondary treated water to irrigate landscaping and the potential use of recycled water if the SSLOCS D waste water treatment plant were upgraded to provide tertiary treatment. By providing tertiary treatment up to 189 AFY of potential demand could be satisfied.

The City of Pismo Beach also has evaluated use of recycled water. As described in their 2010 UWMP, “*the City may begin regional planning efforts regarding recycled water within the next five years*”. The City of Pismo Beach is considering plans to upgrade its waste water treatment plant to provide an anticipated recycled water supply of up to an estimated 1,558 AFY in 2015. This estimate provides an idea of the amount of recycled water that could be available. The City of Pismo Beach UWMP anticipates that the recycled water not used for irrigation near the WWTP and in the Price Canyon development area “*may be applied towards groundwater recharge operations.*”

Lopez Lake Expansion

In 2008, San Luis Obispo County sponsored a preliminary assessment of the concept of installing an inflatable rubber dam at the Lopez Dam spillway. The NCMA is in the process of completing an assessment of dam safety, evaluation of project benefits (including identification of participating parties), identifying alternatives, engineering feasibility studies, environmental review, permitting, design, and construction.

Desalination

In 2006, Arroyo Grande, Grover Beach, and Oceano CSD utilized Prop 50 funds to complete a feasibility study on desalination as an additional water supply option for the NCMA. This alternative supply is not considered to be a viable option at this time.

Nacimiento Pipeline Extension

In 2006, Arroyo Grande, Grover Beach, and Oceano CSD completed a Nacimiento pipeline extension evaluation to determine the feasibility of delivery water from the Nacimiento reservoir to the NCMA. This alternative supply is not considered to be a viable option at this time.

7 References Cited

California Department of Water Resources. 1970. Sea-Water Intrusion: Pismo-Guadalupe Area. Bulletin No. 63-3,76 p.

California Department of Water Resources. 2002. Water resources of the Arroyo Grande – Nipomo Mesa area: Southern District Report, 156 p.

Carollo Engineers. 2011. City of Pismo Beach 2010 Urban Water Management Plan.

City of Arroyo Grande. 2010. City of Arroyo Grande 2010 Urban Water Management Plan.

City of Grover Beach. 2010. City of Grover Beach 2010 Urban Water Management Plan
EDAW, Inc. August 1998. San Luis Obispo County Master Water Plan Update.

GEI Consultants. 2011. 2010 Annual Monitoring Report, Northern Cities Management area.
GEI Consultants. April 2010.

Miller, G. A. and Evenson, R. E. 1966. Utilization of Groundwater in the Santa Maria Valley Area, California. USGS Water Supply Paper 1819-A.

NMMA Technical Group. 2011. Nipomo Mesa Management Area, 2nd Annual Report, Calendar Year 2010.


Superior Court of California, County of Santa Clara, in *Judgment After Trial*, entered January 25, 2008 incorporating *2002 Settlement Agreement among the Northern Cities, Northern Landowners, and Other Parties*, and *2005 Settlement Stipulation for the Santa Maria groundwater basin adjudication*.




Todd Engineers. 2007. Water Balance Study for the Northern Cities Area. Todd Engineers. April 2007.


Todd Engineers. 2010. 2009 Annual Monitoring Report, Northern Cities Management area. Todd Engineers April 2010.

Todd Engineers. 2010. Summary of Renovations for the Northern Cities Management Area Sentry Wells, San Luis Obispo County, California

Wallace Group, 2010. Survey Report on the “Sentry” Well Elevation Establishment for Cities of Arroyo Grande, Grover Beach, Pismo Beach and the Oceano Community Services District



-  Adjudication Area Boundary
-  Santa Maria River Valley Groundwater Basin
-  County Line



2011 Annual Monitoring Report
San Luis Obispo and Santa Barbara Counties


Northern Cities Management Area



SANTA MARIA RIVER VALLEY
GROUNDWATER BASIN

APRIL 2012


FIGURE 1



● City

Adjudication Area Boundary

- Northern Cities Management Area
- Nipomo Mesa Management Area



2011 Annual Monitoring Report
San Luis Obispo County

Northern Cities Management Area






NORTHERN CITIES MANAGEMENT AREA





MARCH 2012


FIGURE 2


Figure 3 - Annual Precipitation 1950-2011













20-Mar-2012 Z:\Projects\116660_NCMA\Fig7_SentryWells.mxd RS

SOURCE: Todd Engineers, 2010.

Figure 8 - Depths of Sentry Wells



25-Apr-2012 Z:\Projects\116660_NCMA\Fig9_GW Elevations_Apr2011.mxd RS



2011 Annual Monitoring Report

Northern Cities Management Area












APRIL 2012

Groundwater Elevation Contours Spring 2011






FIGURE 9A

25-Apr-2012 Z:\Projects\116660_NCMA\Fig9_GW Elevations_Oct2011.mxd RS







LEGEND
 Selected Well





LEGEND


- ⊕ Sentry Well
- ◆ Shallow Well
- Intermediate Well
- ▲ Deep Well











2011 ANNUAL MONITORING REPORT






Northern Cities Management Area








APRIL 2012

WATER ELEVATION, CONDUCTIVITY, AND TEMPERATURE, WELL 30N02

FIGURE 12E



LEGEND
 ⊕ Selected Well



LEGEND
 Selected Well

Figure 15 - Schoeller Diagram for Sentry Well 30N02, 2010-2012

